
A MEMBER OF THE STOHL GROUP OF COMPANIES

December 28, 2016

Mr. John Robertson
Forestville Central School District
Director of Facilities
4 Academy Street
Forestville, NY 14062

Re: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Robertson:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Forestville Central School District, including:

- Forestville Middle / High School, 4 Academy Street, Forestville, NY 14062

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 11, 2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 25 sources of potable water in Forestville Middle / High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Forestville Central School District.

Sincerely,
Stohl Environmental, LLC.



William K. Sisco
Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

**Mr. John Robertson
Forestville Central School District
Director of Facilities
4 Academy Street
Forestville, NY 14062**

Prepared by:



ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219

☎ (716) 312-0070 📠 (716) 312-8092

www.stohlenvironmental.com

Conditions as of October 11, 2016

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Forestville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Forestville Middle / High School, 4 Academy Street, Forestville, NY 14062

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Forestville Middle / High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water in was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
 - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
 - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

| Building Name | Date of Sample Event | Total Number Samples Collected | First Draw Samples | | Confirmatory Samples ** | |
|----------------------------------|----------------------|--------------------------------|------------------------------------------------|------------------------------------------------|------------------------------------------------|------------------------------------------------|
| | | | Number of Samples Below Action level of 15 ppb | Number of Samples Above Action Level of 15 ppb | Number of Samples Below Action level of 15 ppb | Number of Samples Above Action Level of 15 ppb |
| Forestville Middle / High School | 10/11/2016 | 98 | 73 | 25 | 0 | 0 |

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation:

| Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|-------------|----------------------------------------------------------|---------------------|----------------------------|
| Sample # | Sample Type | Classroom or other Location | Fixture/Outlet type | Laboratory Analysis in ppb |
| 101.1-3 | First Draw | Lunch Line Room, Adj to Door to Kitchen | Sink | 24.0 |
| 101.1-10 | First Draw | Kitchen, Steam Pot, Right-Facing Cafeteria | Steam Pot | 24.6 |
| 101.1-14 | First Draw | Janitor's Closet, 320A Adj to Men's Room | Slop Sink | 34.6 |
| 101.1-19 | First Draw | Room 313, Hallway Wall, Adj to Stair | Sink | 34.3 |
| 101.1-22 | First Draw | Room 312, Against Exterior Wall | Sink | 187 |
| 101.1-23 | First Draw | Room 312, Fume Hood | Sink | 476 |
| 101.1-28 | First Draw | Room 304, Right Sink, Closet to Hall (Facing Ext Wall) | Sink | 22.2 |
| 101.1-31 | First Draw | Room 304, Left Sink, Further From Hall (Facing Ext Wall) | Sink | 28.8 |
| 101.1-48 | First Draw | Room 203, Along Hallway Wall, Closer to Door | Sink | 62.5 |
| 101.1-54 | First Draw | Room 204 | Sink | 25.4 |
| 101.1-55 | First Draw | Room 205, Closer to Door | Sink | 28.4 |
| 101.1-57 | First Draw | Universal Lavatory, Near Stair and Boiler Room 100 | Sink | 21.2 |
| 101.1-59 | First Draw | Universal Lavatory, Room 122B | Sink | 34.0 |
| 101.1-60 | First Draw | Room 103 | Sink | 21.0 |
| 101.1-77 | First Draw | Women's Coach's Office | Sink | 64.5 |
| 101.1-79 | First Draw | Men's Coach's Office | Sink | 110 |
| 101.1-82 | First Draw | Boy's Locker Room, Left Sink (Facing Sinks) | Sink | 17.4 |

A MEMBER OF THE STOHL GROUP OF COMPANIES

| Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples (Continued) | | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|------------------------------------------|---------------------|----------------------------|
| Sample # | Sample Type | Classroom or other Location | Fixture/Outlet type | Laboratory Analysis in ppb |
| 101.1-86 | First Draw | Room 111 C, Maintenance Storage | Bubbler | 176 |
| 101.1-91 | First Draw | Boy's Lavatory, Left Sink (Facing Sinks) | Sink | 23.4 |
| 101.1-92 | First Draw | Girl's Lavatory | Hose Bib | 900 |
| 101.1-93 | First Draw | Boy's Lavatory | Hose Bib | 1660 |
| 101.1-95 | First Draw | Exterior, Adj to Music Classroom 105 | Hose Bib | 17.8 |
| 101.1-96 | First Draw | Exterior, Adj to Stage 107A | Hose Bib | 44.6 |
| 101.1-97 | First Draw | Exterior, Adj to Fitness Area 108B | Hose Bib | 29.2 |
| 101.1-98 | First Draw | Exterior, Adj to Distance Learning 114 | Hose Bib | 2340 |

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.4 Laboratory Analytical Reports by Building

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

| | | |
|------------------------------------------------------------|------------------------------------|---------------------------|
| Lab No.: 6058175 Client No.: 101.1-1 WMF | Location: Boiler Room-HB | Result(ppb): 6.40 |
| Lab No.: 6058176 Client No.: 101.1-2 WMTC | Location: Boiler Room-HB | Result(ppb): <2.00 |
| Lab No.: 6058177 Client No.: 101.1-3 | Location: Lunch Line Room-S | Result(ppb): 24.0 |
| Lab No.: 6058178 Client No.: 101.1-4 | Location: Lunch Line Room-S | Result(ppb): 9.50 |
| Lab No.: 6058179 Client No.: 101.1-5 | Location: Kitchen-S | Result(ppb): 12.6 |
| Lab No.: 6058180 Client No.: 101.1-6 | Location: Kitchen-S | Result(ppb): 11.2 |
| Lab No.: 6058181 Client No.: 101.1-7 | Location: Kitchen-S | Result(ppb): 7.30 |
| Lab No.: 6058182 Client No.: 101.1-8 | Location: Kitchen-S | Result(ppb): 2.60 |
| Lab No.: 6058183 Client No.: 101.1-9 | Location: Kitchen-S | Result(ppb): 3.10 |

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6058184 **Location:**Kitchen-SP **Result(ppb):**24.6
Client No.:101.1-10

Lab No.:6058185 **Location:**Kitchen-SP **Result(ppb):**8.80
Client No.:101.1-11

Lab No.:6058186 **Location:**Kitchen-S **Result(ppb):**6.20
Client No.:101.1-12

Lab No.:6058187 **Location:**3rd Flr Drinking Fountain-DF **Result(ppb):**2.80
Client No.:101.1-13

Lab No.:6058188 **Location:**Janitor's Closet-SS **Result(ppb):**34.6
Client No.:101.1-14

Lab No.:6058189 **Location:**Boy's Lav-S **Result(ppb):**5.60
Client No.:101.1-15

Lab No.:6058190 **Location:**Room 313-S **Result(ppb):**13.8
Client No.:101.1-16

Lab No.:6058191 **Location:**Room 313-S **Result(ppb):**13.8
Client No.:101.1-17

Lab No.:6058192 **Location:**Room 313-S **Result(ppb):**10.3
Client No.:101.1-18

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6058193 **Location:**Room 313-S **Result(ppb):**34.3
Client No.:101.1-19

Lab No.:6058194 **Location:**Room 313-S **Result(ppb):**5.40
Client No.:101.1-20

Lab No.:6058195 **Location:**Room 312-S **Result(ppb):**4.90
Client No.:101.1-21

Lab No.:6058196 **Location:**Room 312-S **Result(ppb):**187
Client No.:101.1-22

Lab No.:6058197 **Location:**Room 312-S **Result(ppb):**476
Client No.:101.1-23

Lab No.:6058198 **Location:**Janitor's Closet-S **Result(ppb):**8.30
Client No.:101.1-24

Lab No.:6058199 **Location:**Hallway Adj. Room 302-DF **Result(ppb):**<2.00
Client No.:101.1-25

Lab No.:6058200 **Location:**Girl's Lav-S **Result(ppb):**7.30
Client No.:101.1-26

Lab No.:6058201 **Location:**Girl's Lav-S **Result(ppb):**<2.00
Client No.:101.1-27

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6058202 **Location:**Room 304-S **Result(ppb):**22.2
Client No.:101.1-28

Lab No.:6058203 **Location:**Room 304-S **Result(ppb):**12.7
Client No.:101.1-29

Lab No.:6058204 **Location:**Room 304-S **Result(ppb):**3.80
Client No.:101.1-30

Lab No.:6058205 **Location:**Room 304-S **Result(ppb):**28.8
Client No.:101.1-31

Lab No.:6058206 **Location:**Room 304-S **Result(ppb):**<2.00
Client No.:101.1-32

Lab No.:6058207 **Location:**Room 305-S **Result(ppb):**8.40
Client No.:101.1-33

Lab No.:6058208 **Location:**Room 306-S **Result(ppb):**3.20
Client No.:101.1-34

Lab No.:6058209 **Location:**Room 306-S **Result(ppb):**5.00
Client No.:101.1-35

Lab No.:6058210 **Location:**Drinking Fountain-DF **Result(ppb):**<2.00
Client No.:101.1-36

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6058211 **Location:**Female Staffing Lav-S **Result(ppb):**2.80
Client No.:101.1-37

Lab No.:6058212 **Location:**Female Staffing Lav-S **Result(ppb):**3.30
Client No.:101.1-38

Lab No.:6058213 **Location:**Female Staffing Lav-SS **Result(ppb):**6.20
Client No.:101.1-39

Lab No.:6058214 **Location:**Drinking Fountain-DF **Result(ppb):**<2.00
Client No.:101.1-40

Lab No.:6058215 **Location:**Boy's Lav-S **Result(ppb):**2.50
Client No.:101.1-41

Lab No.:6058216 **Location:**Boy's Lav-S **Result(ppb):**<2.00
Client No.:101.1-42

Lab No.:6058217 **Location:**Boy's Lav-SS **Result(ppb):**<2.00
Client No.:101.1-43

Lab No.:6058218 **Location:**Girl's Lav-S **Result(ppb):**2.60
Client No.:101.1-44

Lab No.:6058219 **Location:**Girl's Lav-S **Result(ppb):**<2.00
Client No.:101.1-45

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6058220 **Location:**Room 203-S **Result(ppb):**10.0
Client No.:101.1-46

Lab No.:6058221 **Location:**Room 203-S **Result(ppb):**10.7
Client No.:101.1-47

Lab No.:6058222 **Location:**Room 203-S **Result(ppb):**62.5
Client No.:101.1-48

Lab No.:6058223 **Location:**Room 203-S **Result(ppb):**11.7
Client No.:101.1-49

Lab No.:6058224 **Location:**Drinking Fountain-DF **Result(ppb):**<2.00
Client No.:101.1-50

Lab No.:6058225 **Location:**Male Staff Lav-S **Result(ppb):**<2.00
Client No.:101.1-51

Lab No.:6058226 **Location:**Male Staff Lav-S **Result(ppb):**3.20
Client No.:101.1-52

Lab No.:6058227 **Location:**Male Staff Lav-SS **Result(ppb):**14.4
Client No.:101.1-53

Lab No.:6058228 **Location:**Room 204-S **Result(ppb):**25.4
Client No.:101.1-54

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/14/2016


Date Analyzed: 12/21/2016

Signature:



Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6058229 **Location:** Room 205-S **Result(ppb):** 28.4
Client No.: 101.1-55

Lab No.: 6058230 **Location:** Room 205-S **Result(ppb):** 2.90
Client No.: 101.1-56

Lab No.: 6058231 **Location:** Universal Lav-S **Result(ppb):** 21.2
Client No.: 101.1-57

Lab No.: 6058232 **Location:** Drinking Fountain-DF **Result(ppb):** <2.00
Client No.: 101.1-58

Lab No.: 6058233 **Location:** Universal Restroom-S **Result(ppb):** 34.0
Client No.: 101.1-59

Lab No.: 6058234 **Location:** Room 103-S **Result(ppb):** 21.0
Client No.: 101.1-60

Lab No.: 6058235 **Location:** Room 118-S **Result(ppb):** 7.70
Client No.: 101.1-61

Lab No.: 6058236 **Location:** Room 118-S **Result(ppb):** 2.50
Client No.: 101.1-62

Lab No.: 6058237 **Location:** Room 116-S **Result(ppb):** 3.80
Client No.: 101.1-63

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

| | | |
|--------------------------------------------------------|----------------------------------------|---------------------------|
| Lab No.: 6058238 Client No.: 101.1-64 | Location: Room 116 Men's Lav-S | Result(ppb): 12.8 |
| Lab No.: 6058239 Client No.: 101.1-65 | Location: Room 116 Ladies Lav-S | Result(ppb): 6.20 |
| Lab No.: 6058240 Client No.: 101.1-66 | Location: Drinking Fountain-DF | Result(ppb): <2.00 |
| Lab No.: 6058241 Client No.: 101.1-67 | Location: Drinking Fountain-DF | Result(ppb): <2.00 |
| Lab No.: 6058242 Client No.: 101.1-68 | Location: Janitor's Closet-SS | Result(ppb): 10.4 |
| Lab No.: 6058243 Client No.: 101.1-69 | Location: Room 115-S | Result(ppb): 3.20 |
| Lab No.: 6058244 Client No.: 101.1-70 | Location: Room 115-S | Result(ppb): 4.10 |
| Lab No.: 6058245 Client No.: 101.1-71 | Location: Room 114-S | Result(ppb): 2.20 |
| Lab No.: 6058246 Client No.: 101.1-72 | Location: Room 114-S | Result(ppb): 4.10 |

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6058247 **Location:**Room 106-S **Result(ppb):**<2.00
Client No.:101.1-73

Lab No.:6058248 **Location:**Girl's Locker Room-S **Result(ppb):**10.0
Client No.:101.1-74

Lab No.:6058249 **Location:**Girl's Locker Room-S **Result(ppb):**3.90
Client No.:101.1-75

Lab No.:6058250 **Location:**Girl's Locker Room-DF **Result(ppb):**7.60
Client No.:101.1-76

Lab No.:6058251 **Location:**Coache's Office-S **Result(ppb):**64.5
Client No.:101.1-77

Lab No.:6058252 **Location:**Boy's Locker Room-B **Result(ppb):**3.40
Client No.:101.1-78

Lab No.:6058253 **Location:**Coache's Office-S **Result(ppb):**110
Client No.:101.1-79

Lab No.:6058254 **Location:**Boy's Locker Room-DF **Result(ppb):**8.90
Client No.:101.1-80

Lab No.:6058255 **Location:**Boy's Locker Room-S **Result(ppb):**5.80
Client No.:101.1-81

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6058256 **Location:** Boy's Locker Room-S **Result(ppb):** 17.4
Client No.: 101.1-82

Lab No.: 6058257 **Location:** Equipment Room-SS **Result(ppb):** 7.80
Client No.: 101.1-83

Lab No.: 6058258 **Location:** Room 141-S **Result(ppb):** 3.40
Client No.: 101.1-84

Lab No.: 6058259 **Location:** Room 141-S **Result(ppb):** <2.00
Client No.: 101.1-85

Lab No.: 6058260 **Location:** Room 111C-B **Result(ppb):** 176
Client No.: 101.1-86

Lab No.: 6058261 **Location:** Janitor's Closet-SS **Result(ppb):** 3.80
Client No.: 101.1-87

Lab No.: 6058262 **Location:** Ladies Lav-S **Result(ppb):** 4.10
Client No.: 101.1-88

Lab No.: 6058263 **Location:** Ladies Lav-S **Result(ppb):** 12.8
Client No.: 101.1-89

Lab No.: 6058264 **Location:** Boy's Lav-S **Result(ppb):** 4.60
Client No.: 101.1-90

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/14/2016

Date Analyzed: 12/21/2016

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6058265 **Location:** Boy's Lav-S **Result(ppb):** 23.4
Client No.: 101.1-91

Lab No.: 6058266 **Location:** Girl's Lav-HB **Result(ppb):** 900
Client No.: 101.1-92

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 6058267 **Location:** Boy's Lav-HB **Result(ppb):** 1660
Client No.: 101.1-93

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 6058268 **Location:** Ice Machine-IM **Result(ppb):** <2.00
Client No.: 101.1-94

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 6058269 **Location:** Exterior HB-HB **Result(ppb):** 17.8
Client No.: 101.1-95

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 6058270 **Location:** Exterior HB-HB **Result(ppb):** 44.6
Client No.: 101.1-96

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 6058271 **Location:** Exterior HB-HB **Result(ppb):** 29.2
Client No.: 101.1-97

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 6058272 **Location:** Exterior HB-HB **Result(ppb):** 2340
Client No.: 101.1-98

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/14/2016


Date Analyzed: 12/21/2016

Signature:



Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
4169 Allendale Pkwy; Suite 100
Blasdell NY 14219

Report Date: 12/21/2016
Report No.: 521928 - Lead Water
Project: Forestville CSD-Forestville MS And HS; 4
Academy St. 10/11/16
Project No.: 2016L-101

Client: STO708

Appendix to Analytical Report:

Customer Contact: Lab Results Final

Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com

iATL Office Manager: cdavis@iatl.com

iATL Account Representative: Shirley Clark

Sample Login Notes: See Batch Sheet Attached

Sample Matrix: Water

Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.5 Laboratory Certifications



Department of Health

ANDREW M. CUOMO
Governor

HOWARD A. ZUCKER, M.D., J.D.
Commissioner

SALLY DRESLIN, M.S., R.N.
Executive Deputy Commissioner

LAB ID: 11021

April 01, 2016

MR. FRANK E. EHRENFELD III
INTERNATIONAL ASBESTOS TESTING LABS
9000 COMMERCE PARKWAY
SUITE B
MT LAUREL, NJ 08054

Certificate Expiration Date:
April 01, 2017

Dear Mr. Ehrenfeld Iii,

Enclosed are certificate(s) of approval issued to your environmental laboratory for the current permit year. The certificate(s) supersede(s) any previously issued one(s) and is(are) in effect through the expiration date listed. Please carefully examine the certificate(s) to insure that the categories, subcategories, analytes, and methods for which your laboratory is approved are correct. In addition, verify that your laboratory's name, address, lead technical director, and identification number are accurate.

Pursuant to NYCRR Subpart 55-2.2, original certificates must be posted conspicuously in the laboratory and copies shall be made available to any client of the laboratory upon request.

Pursuant to NYCRR Subpart 55-2.6, any misrepresentation of the fields of accreditation (category - method - analyte) for which your laboratory is approved may result in denial, suspension, or revocation of your certification. Any use of the Environmental Laboratory Approval Program (ELAP) or National Environmental Laboratory Accreditation Program (NELAP) name, reference to the laboratory's approval status, and/or using the NELAP logo in any catalogs, advertising, business solicitations, proposals, quotations, laboratory analytical reports, or other materials must include the laboratory's ELAP identification number and distinguish between testing for which the laboratory is approved and testing for which the laboratory is not approved.

If you have any questions, please contact ELAP at the New York State Department of Health (NYS DOH), Wadsworth Center, PO Box 509, Albany NY, 12201-0509; by phone at (518) 485-5570; by facsimile at (518) 485-5568; and by email at elap@health.ny.gov.

Sincerely,

Michael P. Ryan, M.T. (ASCP), Ph.D.
Director, Division of Laboratory Quality Certification
Environmental Laboratory Approval Program

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FRANK E. EHRENFELD III
INTERNATIONAL ASBESTOS TESTING LABS
9000 COMMERCE PARKWAY SUITE B
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021


is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved subcategories and/or analytes are listed below:

Metals I

Lead, Total ASTM D3559-90, 96, 03 & 08 (D)

Miscellaneous

Asbestos EPA 100.1
EPA 100.2



Department
of Health

Serial No.: 54134

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FRANK E. EHRENFELD III
INTERNATIONAL ASBESTOS TESTING LABS
9000 COMMERCE PARKWAY SUITE B
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Characteristic Testing

TCLP EPA 1311

Metals I

Lead, Total EPA 7000B

Miscellaneous

Asbestos in Friable Material Item 198.1 of Manual
EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM Item 198.6 of Manual (NOB by PLM)
Asbestos in Non-Friable Material-TEM Item 198.4 of Manual
Lead in Dust Wipes EPA 7000B
Lead in Paint EPA 7000B

Sample Preparation Methods

EPA 3050B

Serial No.: 54135

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FRANK E. EHRENFELD III
INTERNATIONAL ASBESTOS TESTING LABS
9000 COMMERCE PARKWAY SUITE B
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS
All approved subcategories and/or analytes are listed below:*

Metals I

Lead, Total NIOSH 7082

Miscellaneous

Asbestos 40 CFR 763 APXA No. III

NIOSH 7402

Fibers NIOSH 7400 A RULES

NEW
YORK
STATE

Department
of Health

Serial No.: 54136

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.6 Chains of Custody



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) IATL

STOHL Job # 2016L-101

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Middle School and High School

Location: 4 Academy St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

| Sample # | Location | Outlet Type | Time | Cooler Model | Lab ID | Results |
|--------------|---------------------------|-------------|-------|--------------|---------|---------|
| 101.1-1 WMF | Boiler Room | HB | 1:03 | NA | 6058175 | |
| 101.1-2 WMTC | Boiler Room | HB | 1:10 | NA | 6058176 | |
| 101.1-3 | Lunch line room | S | 22:14 | NA | 6058177 | |
| 101.1-4 | Lunch line room | S | 22:14 | NA | 6058178 | |
| 101.1-5 | Kitchen | S | 22:16 | NA | 6058179 | |
| 101.1-6 | Kitchen | S | 22:22 | NA | 6058180 | |
| 101.1-7 | Kitchen | S | 22:22 | NA | 6058181 | |
| 101.1-8 | Kitchen | S | 22:23 | NA | 6058182 | |
| 101.1-9 | Kitchen | S | 22:23 | NA | 6058183 | |
| 101.1-10 | Kitchen | SP | 22:24 | NA | 6058184 | |
| 101.1-11 | Kitchen | SP | 22:24 | NA | 6058185 | |
| 101.1-12 | Kitchen | S | 22:24 | NA | 6058186 | |
| 101.1-13 | 3rd FLR Drinking Fountain | DF | 22:34 | NA | 6058187 | |
| 101.1-14 | Janitor's Closet | SS | 22:35 | NA | 6058188 | |
| 101.1-15 | Boys Lav | S | 22:35 | NA | 6058189 | |
| 101.1-16 | Room 313 | S | 22:37 | NA | 6058190 | |
| 101.1-17 | Room 313 | S | 22:37 | NA | 6058191 | |
| 101.1-18 | Room 313 | S | 22:37 | NA | 6058192 | |

Notes:

Please e-mail lab results to labs@stohlenv.com

☐ If checked, also e-mail results to:

DEC 23 2016

Sampled By: Peter L Zaffram Print Name Peter L Zaffram Date: 10/11/2016

Relinquished By: [Signature] Print Name Joseph Mecca Date: 10/12/2016

Received (Name / Lab): _____ Date: _____

Sample Login (Name / Lab): W101416 Date: _____

Analysis (Name / Lab): AMS 12/23/16 Date: _____

QA/QC Review (Name / Lab): ML Date: 12/23/16

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____

RECEIVED
Time: _____
Time: _____
Time: _____
Time: OCT 14 2016
Time: _____
ATL - By [Signature]



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) IATL

STOHL Job # 2016L-101

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Middle School and High School

Location: 4 Academy St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

| Sample # | Location | Outlet Type | Time | Cooler Model | Lab ID | Results |
|----------|-----------------------|-------------|-------|--------------|---------|---------|
| 101.1-19 | Room 313 | S | 22:37 | NA | 6058193 | |
| 101.1-20 | Room 313 | S | 22:38 | NA | 6058194 | |
| 101.1-21 | Room 312 | S | 22:45 | NA | 6058195 | |
| 101.1-22 | Room 312 | S | 22:45 | NA | 6058196 | |
| 101.1-23 | Room 312 | S | 22:45 | NA | 6058197 | |
| 101.1-24 | Janitor's Closet | S | 22:47 | NA | 6058198 | |
| 101.1-25 | Hallway adj. Room 302 | DF | 22:50 | NA | 6058199 | |
| 101.1-26 | Girls Lav | S | 22:51 | NA | 6058200 | |
| 101.1-27 | Girls Lav | S | 22:51 | NA | 6058201 | |
| 101.1-28 | Room 304 | S | 22:53 | NA | 6058202 | |
| 101.1-29 | Room 304 | S | 22:53 | NA | 6058203 | |
| 101.1-30 | Room 304 | S | 22:53 | NA | 6058204 | |
| 101.1-31 | Room 304 | S | 22:53 | NA | 6058205 | |
| 101.1-32 | Room 304 | S | 22:53 | NA | 6058206 | |
| 101.1-33 | Room 305 | S | 22:56 | NA | 6058207 | |
| 101.1-34 | Room 306 | S | 22:57 | NA | 6058208 | |
| 101.1-35 | Room 306 | S | 22:57 | NA | 6058209 | |
| 101.1-36 | Drinking Fountain | DF | 23:00 | EBFS-8-1A | 6058210 | |

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Peter L Zaffram Print Name Stohl Env: Peter L Zaffram Date: 10/11/2016

Relinquished By: [Signature] Print Name Stohl Env: Joseph Mecca Date: 10/12/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) IATL

STOHL Job # 2016L-101

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Middle School and High School

Location: 4 Academy St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

| Sample # | Location | Outlet Type | Time | Cooler Model | Lab ID | Results |
|----------|-------------------|-------------|-------|--------------|---------|---------|
| 101.1-37 | Female Staff Lav | S | 23:02 | NA | 6058211 | |
| 101.1-38 | Female Staff Lav | S | 23:03 | NA | 6058212 | |
| 101.1-39 | Female Staff Lav | SS | 23:03 | NA | 6058213 | |
| 101.1-40 | Drinking Fountain | DF | 23:09 | EWA-14-1A | 6058214 | |
| 101.1-41 | Boys Lav | S | 23:10 | NA | 6058215 | |
| 101.1-42 | Boys Lav | S | 23:10 | NA | 6058216 | |
| 101.1-43 | Boys Lav | SS | 23:11 | NA | 6058217 | |
| 101.1-44 | Girls Lav | S | 23:16 | NA | 6058218 | |
| 101.1-45 | Girls Lav | S | 23:16 | NA | 6058219 | |
| 101.1-46 | Room 203 | S | 23:20 | NA | 6058220 | |
| 101.1-47 | Room 203 | S | 23:20 | NA | 6058221 | |
| 101.1-48 | Room 203 | S | 23:20 | NA | 6058222 | |
| 101.1-49 | Room 203 | S | 23:20 | NA | 6058223 | |
| 101.1-50 | Drinking Fountain | DF | 23:24 | NA | 6058224 | |
| 101.1-51 | Male Staff Lav | S | 23:25 | NA | 6058225 | |
| 101.1-52 | Male Staff Lav | S | 23:25 | NA | 6058226 | |
| 101.1-53 | Male Staff Lav | SS | 23:25 | NA | 6058227 | |
| 101.1-54 | Room 204 | S | 23:27 | NA | 6058228 | |

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Peter L Zaffram Print Name Stohl Env: Peter L Zaffram Date: 10/11/2016

Relinquished By: [Signature] Print Name Stohl Env: Joseph Mecca Date: 10/12/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) IATL

STOHL Job # 2016L-101

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Middle School and High School

Location: 4 Academy St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

| Sample # | Location | Outlet Type | Time | Cooler Model | Lab ID | Results |
|----------|---------------------|-------------|-------|--------------|---------|---------|
| 101.1-55 | Room 205 | S | 23:28 | NA | 6058229 | |
| 101.1-56 | Room 205 | S | 23:28 | NA | 6058230 | |
| 101.1-57 | Universal Lav | S | 23:28 | NA | 6058231 | |
| 101.1-58 | Drinking Fountain | DF | 23:31 | NA | 6058232 | |
| 101.1-59 | Universal Restroom | S | 23:40 | NA | 6058233 | |
| 101.1-60 | Room 103 | S | 23:42 | NA | 6058234 | |
| 101.1-61 | Room 118 | S | 23:48 | NA | 6058235 | |
| 101.1-62 | Room 118 | S | 23:48 | NA | 6058236 | |
| 101.1-63 | Room 116 | S | 23:51 | NA | 6058237 | |
| 101.1-64 | Room 116 Men's Lav | S | 23:51 | NA | 6058238 | |
| 101.1-65 | Room 116 Ladies Lav | S | 23:51 | NA | 6058239 | |
| 101.1-66 | Drinking Fountain | DF | 0:02 | EZOTL8_1C | 6058240 | |
| 101.1-67 | Drinking Fountain | DF | 0:02 | NA | 6058241 | |
| 101.1-68 | Janitor's Closet | SS | 0:03 | NA | 6058242 | |
| 101.1-69 | Room 115 | S | 0:04 | NA | 6058243 | |
| 101.1-70 | Room 115 | S | 0:04 | NA | 6058244 | |
| 101.1-71 | Room 114 | S | 0:05 | NA | 6058245 | |
| 101.1-72 | Room 114 | S | 0:05 | NA | 6058246 | |

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Peter L Zaffram Print Name Stohl Env: Peter L Zaffram Date: 10/11/2016

Relinquished By:  Print Name Stohl Env: Joseph Mecca Date: 10/12/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) IATL

STOHL Job # 2016L-101

Client: Forestville CSD Contact: John Robertson

Building: Forestville Middle School and High School Location: 4 Academy St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 Days

| Sample # | Location | Outlet Type | Time | Cooler Model | Lab ID | Results |
|----------|-------------------|-------------|------|--------------|---------|---------|
| 101.1-73 | Room 106 | S | 0:07 | NA | 6058247 | |
| 101.1-74 | Girls Locker Room | S | 0:16 | NA | 6058248 | |
| 101.1-75 | Girls Locker Room | S | 0:16 | NA | 6058249 | |
| 101.1-76 | Girls Locker Room | DF | 0:16 | NA | 6058250 | |
| 101.1-77 | Coaches Office | S | 0:17 | NA | 6058251 | |
| 101.1-78 | Boys Locker Room | B | 0:21 | NA | 6058252 | |
| 101.1-79 | Coaches Office | S | 0:23 | NA | 6058253 | |
| 101.1-80 | Boys Locker Room | DF | 0:23 | NA | 6058254 | |
| 101.1-81 | Boys Locker Room | S | 0:23 | NA | 6058255 | |
| 101.1-82 | Boys Locker Room | S | 0:24 | NA | 6058256 | |
| 101.1-83 | Equipment Room | SS | 0:31 | NA | 6058257 | |
| 101.1-84 | Room 141 | S | 0:32 | NA | 6058258 | |
| 101.1-85 | Room 141 | S | 0:34 | NA | 6058259 | |
| 101.1-86 | Room 111C | B | 0:36 | NA | 6058260 | |
| 101.1-87 | Janitors Closet | SS | 0:37 | NA | 6058261 | |
| 101.1-88 | Ladies Lav | S | 0:40 | NA | 6058262 | |
| 101.1-89 | Ladies Lav | S | 0:40 | NA | 6058263 | |
| 101.1-90 | Boys Lav | S | 0:42 | NA | 6058264 | |

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Peter L Zaffram Print Name Stohl Env: Peter L Zaffram Date: 10/11/2016

Relinquished By: [Signature] Print Name Stohl Env: Joseph Mecca Date: 10/12/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

