



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

October 13, 2016

Mr. John Robertson  
Forestville Central School District  
Director of Facilities  
4 Academy Street  
Forestville, NY 14062

**re: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. John Robertson:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Forestville Central School District, including:

- Forestville Elementary School, 12 Water Street, Forestville, NY

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than or equal to the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on September 17, 2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 23 sources of potable water in Forestville Elementary have been identified as having lead concentrations in water at or above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Forestville Central School District.

Sincerely,  
Stohl Environmental, LLC.

A handwritten signature in black ink, appearing to read "William K. Sisco".

William K. Sisco  
PROJECT MANAGER

I

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**Mr. John Robertson  
Forestville Central School District  
Director of Facilities  
4 Academy Street  
Forestville, NY 14062**

**Prepared by:**



**ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES**

**4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219**

**☎ (716) 312-0070 📠 (716) 312-8092**

**[www.stohlenvironmental.com](http://www.stohlenvironmental.com)**

**Conditions as of September 17, 2016**



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

## 1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Forestville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Forestville Elementary School, 12 Water Street, Forestville, NY

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Forestville Elementary. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **‘3Ts for Reducing Lead in Drinking Water in Schools’**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water in was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
  - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
  - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
 Buffalo, New York 14219  
 (P) 716-312-0070 (F) 716-312-8092  
 www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.2 Executive Summary of Sampling and Analysis:

First Draw Samples				Confirmatory Samples **		
Building Name	Total Number of Samples Collected	Number of Samples Analyzed Below the NYS Action level of 15 ppb	Number of Samples Analyzed at or above the NYS Action Level of 15 ppb	Total Number of Samples Collected	Number of Samples Analyzed Below the NYS Action level of 15 ppb	Number of Samples Analyzed Below the NYS Action level of 15 ppb
Forestville Elementary	84	61	23	0	0	0

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
 Buffalo, New York 14219  
 (P) 716-312-0070 (F) 716-312-8092  
 www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Locations of Samples Analyzed at or above the NYS Action Level of 15 parts per billion			
Sample #	Classroom or other Location	Outlet type	Laboratory Analysis
101.3-5	Classroom 12	Sink	19.0
101.3-16	Business Office	Sink (incorrectly listed as Bubbler on chain and lab reports)	16.3
101.3-17	Men's Lavatory Sink	Sink	16.7
101.3-29	Kitchen South Wall Sink	Sink	54.2
101.3-33	Gym Teacher Office Sink	Sink	82.5
101.3-34	Girls Locker Room Sink	Sink	22.0
101.3-49	Classroom 29	Steel Sink	27.8
101.3-55	Classroom 31	Steel Sink	23.6
101.3-58	Classroom 30	Steel Sink	15.7
101.3-61	Classroom 33	Steel Sink	103
101.3-69	Classroom 36	Sink	69.1
101.3-70	Classroom 36	Bubbler	32.6
101.3-71	Classroom 40	Steel Sink	60.0
101.3-72	Classroom 40	Bubbler	24.9
101.3-74	Classroom 39	Bubbler	39.5
101.3-77	Classroom 41	Sink	23.9
101.2-78	Classroom 41	Bubbler	26.5
101.3-79	Hose Bib, 1 <sup>st</sup> North of front doors	Hose Bib	45.1
101.3-80	Hose Bib, 2 <sup>nd</sup> North of front doors	Hose Bib	108
101.3-81	Hose Bib, North side of building	Hose Bib	2140
101.3-82	Hose Bib, Northeast most	Hose Bib	74.3
101.3-83	Hose Bib, East central	Hose Bib	554
101.3-84	Hose Bib, Southeast	Hose Bib	48.9



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

### 1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.4 Laboratory Analytical Reports by Building





Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix: Water
Received: 09/21/16
Analyzed: 09/29/16
Reported: 10/03/16

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Sample Date, Result, RL\*, Units, Analyst. Rows include sample IDs 185406-001 through 185406-015 with corresponding lead levels and locations.

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix: Water
Received: 09/21/16
Analyzed: 09/29/16
Reported: 10/03/16

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location Method, Sample Date, Result, RL\*, Units, Analyst. Rows include various sample IDs (e.g., 185406-016) and locations (e.g., Business Office Bubblers, Men's Lavatory Sink).

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
Blasdell, NY 14219

<b>Order #:</b>	185406
-----------------	--------

**Matrix** Water  
**Received** 09/21/16  
**Analyzed** 09/30/16  
**Reported** 10/03/16

**PO Number:**

**Attn:**  
**Project:** Forestville Elementary  
**Location:** 12 Water St Forestville NY  
**Number:** 2016L-101.3

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
<b>185406-030</b>	101.3-30	Nurse BR Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-031</b>	101.3-31	Nurse Exam Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-032</b>	101.3-32	DF Hallway Near Gym DF					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-033</b>	101.3-33	Gym Teacher Office Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	82.5	25.0	µg/L	SA
<b>185406-034</b>	101.3-34	Girls Locker Room Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	22.0	5.00	µg/L	SA
<b>185406-035</b>	101.3-35	Girls Locker Room Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.01	5.00	µg/L	SA
<b>185406-036</b>	101.3-36	Boys Locker Room Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	10.3	5.00	µg/L	SA
<b>185406-037</b>	101.3-37	Classroom 25 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-038</b>	101.3-38	Classroom 25 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-039</b>	101.3-39	Classroom 25 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.88	5.00	µg/L	SA
<b>185406-040</b>	101.3-40	Classroom 24 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-041</b>	101.3-41	Classroom 24 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-042</b>	101.3-42	Classroom 24 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.17	5.00	µg/L	SA
<b>185406-043</b>	101.3-43	Classroom 27 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-044</b>	101.3-44	Classroom 27 Bubblers					

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

# Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

**Customer:** Stohl Environmental, LLC (4507)  
**Address:** 4169 Allendale Parkway  
Blasdell, NY 14219

<b>Order #:</b>	185406
-----------------	--------

**Matrix** Water  
**Received** 09/21/16  
**Analyzed** 09/30/16  
**Reported** 10/03/16

**PO Number:**

**Attn:**  
**Project:** Forestville Elementary  
**Location:** 12 Water St Forestville NY  
**Number:** 2016L-101.3

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-045</b>	101.3-45	Classroom 27 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.65	5.00	µg/L	SA
<b>185406-046</b>	101.3-46	Classroom 26 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.39	5.00	µg/L	SA
<b>185406-047</b>	101.3-47	Classroom 26 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-048</b>	101.3-48	Classroom 26 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.67	5.00	µg/L	SA
<b>185406-049</b>	101.3-49	Classroom 29 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	27.8	5.00	µg/L	SA
<b>185406-050</b>	101.3-50	Classroom 29 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-051</b>	101.3-51	Classroom 29 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.84	5.00	µg/L	SA
<b>185406-052</b>	101.3-52	Classroom 28 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.50	5.00	µg/L	SA
<b>185406-053</b>	101.3-53	Classroom 28 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-054</b>	101.3-54	Classroom 28 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-055</b>	101.3-55	Classroom 31 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	23.6	5.00	µg/L	SA
<b>185406-056</b>	101.3-56	Classroom 31 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.77	5.00	µg/L	SA
<b>185406-057</b>	101.3-57	Classroom 31 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
<b>185406-058</b>	101.3-58	Classroom 30 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	15.7	5.00	µg/L	SA

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix: Water
Received: 09/21/16
Analyzed: 09/30/16
Reported: 10/03/16

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Sample Date, Result, RL\*, Units, Analyst. Rows include sample details for various locations like Classroom 30, 33, 34, and 36, with results for Lead.

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix: Water
Received: 09/21/16
Analyzed: 10/01/16
Reported: 10/03/16

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Sample Date, Result, RL\*, Units, Analyst. Contains 20 rows of lead test data for various locations like Classroom 39 Sink, Classroom 44 Steel Sink, etc.

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

Order #: 185406

Matrix: Water
Received: 09/21/16
Analyzed: 10/01/16
Reported: 10/03/16

PO Number:

Table with 7 columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Sample Date, Result, RL\*, Units, Analyst

185406-10/03/16 03:34 PM

Abisola O Kasali

Reviewed By: Abisola Kasali
Metals Supervisor

\*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD Contact: John Robertson

Building: Forestville Elementary Location: 12 Water St., Forestville, NY

<b>LEAD</b>	<i>Turnaround</i>
Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 <u>X</u>	<u>5 days</u>

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-1 WMF	water main outside hose bib	Hose Bib	7:28	NA		
101.3-2 WMTC	water main outside hose bib	Hose Bib	7:28	NA		
101.3-3	Classroom 13	Sink	7:40	NA		
101.3-4	Classroom 13	Bubbler	7:41	NA		
101.3-5	Classroom 12	Sink	7:48	NA		
101.3-6	Classroom 12	Bubbler	7:49	NA		
101.3-7	Classroom 11	Sink	7:54	NA		
101.3-8	Classroom 11	Bubbler	7:54	NA		
101.3-9	Classroom 10	Sink	7:53	NA		
101.3-10	Classroom 10	Bubbler	7:53	NA		
101.3-11	Classroom 9	Sink	7:59	NA		
101.3-12	Classroom 9	Bubbler	8:00	NA		
101.3-13	Classroom 8	Sink	8:03	NA		
101.3-14	Classroom 6 - Staff Lounge	Sink	8:09	NA		
101.3-15	Classroom 6 - Staff Lounge	Bubbler	8:10	NA		
101.3-16	Business Office	Bubbler	8:12	NA		
101.3-17	Men's Lavatory	Sink	10:17	NA		
101.3-18	Girls Bathroom - West sink	Sink	8:14	NA		

185406 S 84  
  
 V:\185\185406  
 fghraizi 9/21/2016 2:4 5:00 PM  
 Federal Express 77726 3873821

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Wang Print Name Stohl Env: Bill Sisco Date: 9/17/2016  
 Relinquished By: Wang Print Name Stohl Env: Bill Sisco Date: 9/19/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider  
 STOHL Job # 2016L-101.3

Client: Forestville CSD Contact: John Robertson  
 Building: Forestville Elementary Location: 12 Water St., Forestville, NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X Turnaround 5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-19	Girls Bathroom - East sink	Sink	8:15	NA		
101.3-20	Mop Room	Janitor Sink	8:24	NA		
101.3-21	Boys Bathroom - West Sink	Sink	8:27	NA		
101.3-22	Boys Bathroom - East Sink	Sink	8:27	NA		
101.3-23	Staff bathroom	Sink	8:25	NA		
101.3-24	Psychology room	Sink	8:29	NA		
101.3-25	DF cafeteria	DF	8:38	NA		
101.3-26	Sink north wall kitchen	Sink	8:41	NA		
101.3-27	Kitchen bathroom	Sink	8:42	NA		
101.3-28	Kitchen East Wall	Sink	8:39	NA		
101.3-29	Kitchen - South Wall	Sink	8:40	NA		
101.3-30	Nurse br	Sink	8:48	NA		
101.3-31	Nurse exam	Sink	8:50	NA		
101.3-32	DF hallway near gym	Drinking Fountain	8:55	Elkay, model: lzwsr1c		
101.3-33	Gym Teacher Office	Sink	9:00	NA		
101.3-34	Girls Locker Room	Sink	9:01	NA		
101.3-35	Girls Locker Room	Bubbler	9:06	NA		
101.3-36	Boys locker room sink	Sink	9:00	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Bill Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016  
 Relinquished By: Bill Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016  
 Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-37	Classroom 25 - Steel sink	Sink	9:15	NA		
101.3-38	Classroom 25	Bubbler	9:15	NA		
101.3-39	Classroom 25 - White sink	Sink	9:16	NA		
101.3-40	Classroom 24, steel sink	Sink	9:23	NA		
101.3-41	Classroom 24, bubbler	Bubbler	9:26	NA		
101.3-42	Classroom 24, white sink	Sink	9:28	NA		
101.3-43	Classroom 27 - Steel sink	Sink	9:28	NA		
101.3-44	Classroom 27	Bubbler	9:28	NA		
101.3-45	Classroom 27 - White sink	Sink	9:29	NA		
101.3-46	Classroom 26, steel sink	Sink	9:32	NA		
101.3-47	Classroom 26, bubbler	bubbler	9:34	NA		
101.3-48	Classroom 26, white sink	Sink	9:36	NA		
101.3-49	Classroom 29 - Steel sink	Sink	9:37	NA		
101.3-50	Classroom 29	bubbler	9:37	NA		
101.3-51	Classroom 29 - White Sink	Sink	9:38	NA		
101.3-52	Classroom 28, steel sink	Sink	9:38	NA		
101.3-53	Classroom, 28, bubbler	Bubbler	9:41	NA		
101.3-54	Classroom 28, white sink	Sink	9:43	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Willie Fann Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willie Fann Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-55	Classroom 31 - Steel sink	Sink	9:41	NA		
101.3-56	Classroom 31	bubbler	9:41	NA		
101.3-57	Classroom 31 - White sink	Sink	9:42	NA		
101.3-58	Classroom 30, steel sink	Sink	9:49	NA		
101.3-59	Classroom 30, bubbler	bubbler	9:50	NA		
101.3-60	Classroom 30, white sink	Sink	9:53	NA		
101.3-61	Classroom 33 - Steel sink	Sink	9:51	NA		
101.3-62	Classroom 33	bubbler	9:51	NA		
101.3-63	Classroom 33 - White sink	Sink	9:52	NA		
101.3-64	Classroom 32, white sink	Sink	9:56	NA		
101.3-65	Outside custodian door	Drinking Fountain	10:03	NA		
101.3-66	Women's Lavatory	Sink	10:09	NA		
101.3-67	Classroom 34, steel sink	Sink	10:22	NA		
101.3-68	Classroom 34, bubbler	bubbler	10:23	NA		
101.3-69	Classroom 36	Sink	10:23	NA		
101.3-70	Classroom 36	Bubbler	10:23	NA		
101.3-71	Classroom 40, steel sink	Sink	10:30	NA		
101.3-72	Classroom 40, bubbler	Bubbler	10:32	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Willie Green Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willie Green Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

*Turnaround*  
5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-73	Classroom 39	Sink	10:33	NA		
101.3-74	Classroom 39	Bubbler	10:33	NA		
101.3-75	Classroom 44, steel sink	Sink	10:37	NA		
101.3-76	Classroom 44, bubbler	Bubbler	10:39	NA		
101.3-77	Classroom 41	Sink	10:38	NA		
101.3-78	Classroom 41	Bubbler	10:38	NA		
101.3-79	Hose bib, 1st N of ft doors	Hose Bib	11:08	NA		
101.3-80	Hose bib, 2nd N of ft doors	Hose bib	11:14	NA		
101.3-81	Hose bib, north side of build.	Hose bib	11:19	NA		
101.3-82	Hose bib, northeast most	Hose bib	11:23	NA		
101.3-83	Hose bib	Hose bib	11:27	NA		
101.3-84	Hose bib	Hose bib	11:34	NA		
101.3-85	Hose bib, southwest	Hose bib	11:37	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Willie Fran Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willie Fran Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued September 22, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total

EPA 200.9 Rev. 2.2



Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES NON POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Lead, Total  
EPA 200.7 Rev. 4.4  
EPA 6010C  
EPA 7000B  
EPA 200.9 Rev. 2.2

**Sample Preparation Methods**

EPA 3010A  
EPA 3005A  
EPA 3020A



Department  
of Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2003) for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved analytes are listed below:*

**Characteristic Testing**

**Polychlorinated Biphenyls**

TCLP EPA 1311

PCB-1268 EPA 8082A

**Metals I**

**Sample Preparation Methods**

Barium, Total EPA 6010C

EPA 3010A

Cadmium, Total EPA 6010C

EPA 3050B

Chromium, Total EPA 6010C

EPA 3550C

Lead, Total EPA 6010C

EPA 3031

EPA 7000B

Nickel, Total EPA 6010C

Silver, Total EPA 6010C

**Metals II**

Antimony, Total EPA 6010C

Arsenic, Total EPA 6010C

Chromium VI EPA 7196A

Mercury, Total EPA 7471B

Selenium, Total EPA 6010C

**Polychlorinated Biphenyls**

PCB-1016 EPA 8082A

PCB-1221 EPA 8082A

PCB-1232 EPA 8082A

PCB-1242 EPA 8082A

PCB-1248 EPA 8082A

PCB-1254 EPA 8082A

PCB-1260 EPA 8082A

PCB-1262 EPA 8082A

NEW  
YORK  
STATE

Department  
of Health

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE  
All approved subcategories and/or analytes are listed below:*

**Miscellaneous**

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

**Sample Preparation Methods**

EPA 3050B



**Serial No.: 54669**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FAYEZ ABOUZAKI  
SCHNEIDER LABORATORIES GLOBAL, INC  
2512 WEST CARY STREET  
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS  
All approved subcategories and/or analytes are listed below:*

**Metals I**

Lead, Total NIOSH 7082  
40 CFR PART 50 1984 APP G

**Miscellaneous**

Fibers NIOSH 7400 A RULES



**Serial No.: 54670**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.6 Chains of Custody



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 ☎ (716) 312-0070 ■ (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-1 WMF	water main outside hose bib	Hose Bib	7:28	NA		
101.3-2 WMTC	water main outside hose bib	Hose Bib	7:28	NA		
101.3-3	Classroom 13	Sink	7:40	NA		
101.3-4	Classroom 13	Bubbler	7:41	NA		
101.3-5	Classroom 12	Sink	7:48	NA		
101.3-6	Classroom 12	Bubbler	7:49	NA		
101.3-7	Classroom 11	Sink	7:54	NA		
101.3-8	Classroom 11	Bubbler	7:54	NA		
101.3-9	Classroom 10	Sink	7:53	NA		
101.3-10	Classroom 10	Bubbler	7:53	NA		
101.3-11	Classroom 9	Sink	7:59	NA		
101.3-12	Classroom 9	Bubbler	8:00	NA		
101.3-13	Classroom 8	Sink	8:03	NA		
101.3-14	Classroom 6 - Staff Lounge	Sink	8:09	NA		
101.3-15	Classroom 6 - Staff Lounge	Bubbler	8:10	NA		
101.3-16	Business Office	Bubbler	8:12	NA		
101.3-17	Men's Lavatory	Sink	10:17	NA		
101.3-18	Girls Bathroom - West sink	Sink	8:14	NA		

Note: outlet type should be "Sink"

Notes:  
 Please e-mail lab results to labs@stohlenv.com  If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Willis Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willis Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**  
 Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround  
5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-19	Girls Bathroom - East sink	Sink	8:15	NA		
101.3-20	Mop Room	Janitor Sink	8:24	NA		
101.3-21	Boys Bathroom - West Sink	Sink	8:27	NA		
101.3-22	Boys Bathroom - East Sink	Sink	8:27	NA		
101.3-23	Staff bathroom	Sink	8:25	NA		
101.3-24	Psychology room	Sink	8:29	NA		
101.3-25	DF cafeteria	DF	8:38	NA		
101.3-26	Sink north wall kitchen	Sink	8:41	NA		
101.3-27	Kitchen bathroom	Sink	8:42	NA		
101.3-28	Kitchen East Wall	Sink	8:39	NA		
101.3-29	Kitchen - South Wall	Sink	8:40	NA		
101.3-30	Nurse br	Sink	8:48	NA		
101.3-31	Nurse exam	Sink	8:50	NA		
101.3-32	DF hallway near gym	Drinking Fountain	8:55	Elkay, model: lzwsr1c		
101.3-33	Gym Teacher Office	Sink	9:00	NA		
101.3-34	Girls Locker Room	Sink	9:01	NA		
101.3-35	Girls Locker Room	Bubbler	9:06	NA		
101.3-36	Boys locker room sink	Sink	9:00	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Bill Sisco Print Name Bill Sisco Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Bill Sisco Print Name Bill Sisco Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-37	Classroom 25 - Steel sink	Sink	9:15	NA		
101.3-38	Classroom 25	Bubbler	9:15	NA		
101.3-39	Classroom 25 - White sink	Sink	9:16	NA		
101.3-40	Classroom 24, steel sink	Sink	9:23	NA		
101.3-41	Classroom 24, bubbler	Bubbler	9:26	NA		
101.3-42	Classroom 24, white sink	Sink	9:28	NA		
101.3-43	Classroom 27 - Steel sink	Sink	9:28	NA		
101.3-44	Classroom 27	Bubbler	9:28	NA		
101.3-45	Classroom 27 - White sink	Sink	9:29	NA		
101.3-46	Classroom 26, steel sink	Sink	9:32	NA		
101.3-47	Classroom 26, bubbler	bubbler	9:34	NA		
101.3-48	Classroom 26, white sink	Sink	9:36	NA		
101.3-49	Classroom 29 - Steel sink	Sink	9:37	NA		
101.3-50	Classroom 29	bubbler	9:37	NA		
101.3-51	Classroom 29 - White Sink	Sink	9:38	NA		
101.3-52	Classroom 28, steel sink	Sink	9:38	NA		
101.3-53	Classroom, 28, bubbler	Bubbler	9:41	NA		
101.3-54	Classroom 28, white sink	Sink	9:43	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Willis Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willis Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

Client: Forestville CSD Contact: John Robertson

Building: Forestville Elementary Location: 12 Water St., Forestville, NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-55	Classroom 31 - Steel sink	Sink	9:41	NA		
101.3-56	Classroom 31	bubbler	9:41	NA		
101.3-57	Classroom 31 - White sink	Sink	9:42	NA		
101.3-58	Classroom 30, steel sink	Sink	9:49	NA		
101.3-59	Classroom 30, bubbler	bubbler	9:50	NA		
101.3-60	Classroom 30, white sink	Sink	9:53	NA		
101.3-61	Classroom 33 - Steel sink	Sink	9:51	NA		
101.3-62	Classroom 33	bubbler	9:51	NA		
101.3-63	Classroom 33 - White sink	Sink	9:52	NA		
101.3-64	Classroom 32, white sink	Sink	9:56	NA		
101.3-65	Outside custodian door	Drinking Fountain	10:03	NA		
101.3-66	Women's Lavatory	Sink	10:09	NA		
101.3-67	Classroom 34, steel sink	Sink	10:22	NA		
101.3-68	Classroom 34, bubbler	bubbler	10:23	NA		
101.3-69	Classroom 36	Sink	10:23	NA		
101.3-70	Classroom 36	Bubbler	10:23	NA		
101.3-71	Classroom 40, steel sink	Sink	10:30	NA		
101.3-72	Classroom 40, bubbler	Bubbler	10:32	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
 (716) 312-0070 (716) 312-8092  
 www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-73	Classroom 39	Sink	10:33	NA		
101.3-74	Classroom 39	Bubbler	10:33	NA		
101.3-75	Classroom 44, steel sink	Sink	10:37	NA		
101.3-76	Classroom 44, bubbler	Bubbler	10:39	NA		
101.3-77	Classroom 41	Sink	10:38	NA		
101.3-78	Classroom 41	Bubbler	10:38	NA		
101.3-79	Hose bib, 1st N of ft doors	Hose Bib	11:08	NA		
101.3-80	Hose bib, 2nd N of ft doors	Hose bib	11:14	NA		
101.3-81	Hose bib, north side of build.	Hose bib	11:19	NA		
101.3-82	Hose bib, northeast most	Hose bib	11:23	NA		
101.3-83	Hose bib	Hose bib	11:27	NA		
101.3-84	Hose bib	Hose bib	11:34	NA		
101.3-85	Hose bib, southwest	Hose bib	11:37	NA		

Notes:  
 Please e-mail lab results to labs@stohlenv.com \_\_\_\_\_

Sampled By: Willis Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willis Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_