

May 19, 2021

Mr. Jim Knoop
Forestville Central School
District Director of Facilities
4 Academy Street
Forestville, New York 14062

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Knoop:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Forestville Central School District, including:

- Forestville Middle/High School – 4 Academy Street, Forestville, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 8, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 13 sources of potable water in the Middle/High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Forestville Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Forestville Central School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of March 8, 2021

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Forestville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Forestville Middle/High School – 4 Academy Street, Forestville, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Middle/High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

| Building Name | Date of Sample Event | Total Number Samples Collected | First Draw Samples | | Confirmatory Samples ** | |
|--------------------|----------------------|--------------------------------|--|--|--|--|
| | | | Number of Samples at or Below Action level of 15 ppb | Number of Samples Above Action Level of 15 ppb | Number of Samples at or Below Action level of 15 ppb | Number of Samples Above Action Level of 15 ppb |
| Middle/High School | 3/8/2021 | 54 | 41 | 13 | N/A | N/A |

** Confirmatory samples are samples collected subsequent to “Step 1” First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

| Sample # | Classroom or other Location | Fixture/Outlet type | Laboratory Analysis in ppb |
|----------|--|---------------------|----------------------------|
| 183.1-3 | Lunch Line Room 115 Northwest Handwash | Sink | 226 |
| 183.1-4 | Lunch Line Room 115 East Wall Handwash | Sink | 26.9 |
| 183.1-6 | Kitchen Hand Wash North Wall | Sink | 91.6 |
| 183.1-8 | Kitchen 3 Bay Sink Right | Sink | 36.4 |
| 183.1-10 | Kitchen Steam Pot Right | Sink | 20.1 |
| 183.1-11 | Kitchen Steam Pot Left | Sink | 29.2 |
| 183.1-34 | Room 306 Left | Sink | 24.8 |
| 183.1-38 | 3 rd Floor Female Staff Lav Right | Sink | 37.3 |
| 183.1-51 | 2 nd Floor Male Staff Lav Left | Sink | 20.5 |
| 183.1-54 | Room 204 | Sink | 22.8 |
| 183.1-56 | Room 205 South | Sink | 17.1 |
| 183.1-74 | Girls Locker Room Left | Sink | 17.2 |
| 183.1-77 | Girls Locker Room Coaches Office | Sink | 65.8 |

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Report Number: 21-03-03464
 Received Date: 03/16/2021
 Reported Date: 04/12/2021
 Sampled By: Christine Schultz
 Tech Certification #:

Project/Test Address: 2020L-183.1; Forestville Middle/High School; 4 Academy St; Forestville, NY

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|---|--------------------------|---------------|--------------|
| 21-03-03464-001 | 183.1-3 | 03/08/2021 | LUNCH LINE ROOM 115 NORTHWEST HANDWASH | 226 | 03/29/2021 | W01 |
| 21-03-03464-002 | 183.1-4 | 03/08/2021 | LUNCH LINE ROOM 115 EAST WALL HANDWASH | 26.9 | 04/08/2021 | |
| 21-03-03464-003 | 183.1-5 | 03/08/2021 | KITCHEN CENTER OF ROOM SINK NORTH SIDE | 12.9 | 04/08/2021 | |
| 21-03-03464-004 | 183.1-6 | 03/08/2021 | KITCHEN HAND WASH NORTH WALL | 91.6 | 04/08/2021 | |
| 21-03-03464-005 | 183.1-7 | 03/08/2021 | KITCHEN 3 BAY SINK LEFT | 11.1 | 04/08/2021 | |
| 21-03-03464-006 | 183.1-8 | 03/08/2021 | KITCHEN 3 BAY SINK RIGHT | 36.4 | 04/08/2021 | |
| 21-03-03464-007 | 183.1-9 | 03/08/2021 | KITCHEN DISH SPRAYER | 3.40 | 04/08/2021 | |
| 21-03-03464-008 | 183.1-10 | 03/08/2021 | KITCHEN STEAM POT RIGHT | 20.1 | 04/08/2021 | |
| 21-03-03464-009 | 183.1-11 | 03/08/2021 | KITCHEN STEAM POT LEFT | 29.2 | 04/08/2021 | |
| 21-03-03464-010 | 183.1-12 | 03/08/2021 | KITCHEN CENTER OF ROOM SINK SOUTH SIDE | 2.77 | 04/08/2021 | |
| 21-03-03464-011 | 183.1-13B | 03/08/2021 | 3RD FLR DRINKING FOUNTAIN | <1.00 | 04/08/2021 | |
| 21-03-03464-012 | 183.1-15 | 03/08/2021 | BOYS LAV 3RD FLOOR BY 313 | 3.83 | 04/08/2021 | |
| 21-03-03464-013 | 183.1-16 | 03/08/2021 | ROOM 313 LEFT | 1.14 | 04/08/2021 | |

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-183.1; Forestville Middle/High School; 4 Academy St; Forestville, NY

Report Number: 21-03-03464

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|----------------------------------|--------------------------|---------------|--------------|
| 21-03-03464-014 | 183.1-17 | 03/08/2021 | ROOM 313 RIGHT | 2.19 | 04/08/2021 | |
| 21-03-03464-015 | 183.1-26 | 03/08/2021 | GIRLS LAV BY 304 LEFT | 5.89 | 04/08/2021 | |
| 21-03-03464-016 | 183.1-27 | 03/08/2021 | GIRLS LAV BY 304 RIGHT | 1.27 | 04/08/2021 | |
| 21-03-03464-017 | 183.1-34 | 03/08/2021 | ROOM 306 LEFT | 24.8 | 04/08/2021 | |
| 21-03-03464-018 | 183.1-35 | 03/08/2021 | ROOM 306 RIGHT | 13.3 | 04/08/2021 | |
| 21-03-03464-019 | 183.1-37 | 03/08/2021 | 3RD FLOOR FEMALE STAFF LAV LEFT | 2.05 | 04/08/2021 | |
| 21-03-03464-020 | 183.1-38 | 03/08/2021 | 3RD FLOOR FEMAIL STAFF LAV RIGHT | 37.3 | 04/08/2021 | |
| 21-03-03464-021 | 143.1-41 | 03/08/2021 | 2ND FLOOR BOYS LAV LEFT | 11.0 | 04/08/2021 | |
| 21-03-03464-022 | 183.1-42 | 03/08/2021 | 2ND FLOOR BOYS LAV RIGHT | 1.18 | 04/08/2021 | |
| 21-03-03464-023 | 183.1-43B | 03/08/2021 | DRINKING FOUNTAIN BY 202 | <1.00 | 04/08/2021 | |
| 21-03-03464-024 | 183.1-44 | 03/08/2021 | 2ND FLOOR GIRLS LAV LEFT | 2.35 | 04/08/2021 | |
| 21-03-03464-025 | 183.1-45 | 03/08/2021 | 2ND FLOOR GIRLS LAV RIGHT | 11.4 | 04/08/2021 | |
| 21-03-03464-026 | 183.1-51 | 03/08/2021 | 2ND FLOOR MALE STAFF LAV LEFT | 20.5 | 04/08/2021 | |
| 21-03-03464-027 | 183.1-52 | 03/08/2021 | 2ND FLOOR MALE STAFF LAV RIGHT | 3.11 | 04/08/2021 | |
| 21-03-03464-028 | 183.1-54 | 03/08/2021 | ROOM 204 | 22.8 | 04/08/2021 | |
| 21-03-03464-029 | 183.1-55 | 03/08/2021 | ROOM 205 NORTH | 3.32 | 04/08/2021 | |
| 21-03-03464-030 | 183.1-56 | 03/08/2021 | ROOM 205 SOUTH | 17.1 | 04/08/2021 | |
| 21-03-03464-031 | 183.1-57 | 03/08/2021 | UNIVERSAL LAV OUTSIDE 101 | 4.88 | 04/08/2021 | |
| 21-03-03464-032 | 183.1-58B | 03/08/2021 | DRINKING FOUNTAIN OUTSIDE 103 | <1.00 | 04/08/2021 | |
| 21-03-03464-033 | 183.1-59 | 03/08/2021 | UNIVERSAL RESTROOM OUTSIDE 103 | 6.80 | 04/08/2021 | |

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03464

Project/Test Address: 2020L-183.1; Forestville Middle/High School; 4 Academy St; Forestville, NY

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|----------------------------------|--------------------------|---------------|--------------|
| 21-03-03464-034 | 183.1-60 | 03/08/2021 | ROOM 103 | 11.3 | 04/08/2021 | |
| 21-03-03464-035 | 183.1-61 | 03/08/2021 | NURSE ROOM 118 LAV | 6.40 | 04/08/2021 | |
| 21-03-03464-036 | 183.1-62 | 03/08/2021 | NURSE ROOM 118 EXAM | 1.94 | 04/08/2021 | |
| 21-03-03464-037 | 183.1-63 | 03/08/2021 | ROOM 116 | 3.18 | 04/08/2021 | |
| 21-03-03464-038 | 183.1-64 | 03/08/2021 | ROOM 116 MENS LAV | 4.17 | 04/08/2021 | |
| 21-03-03464-039 | 183.1-65 | 03/08/2021 | ROOM 116 LADIES LAV | 4.94 | 04/08/2021 | |
| 21-03-03464-040 | 183.1-70 | 03/08/2021 | WOMENS LAV 115 RIGHT | 5.61 | 04/08/2021 | |
| 21-03-03464-041 | 183.1-71 | 03/08/2021 | MENS LAV 114 LEFT | 12.6 | 04/08/2021 | |
| 21-03-03464-042 | 183.1-72 | 03/08/2021 | MENS LAV 114 RIGHT | 11.0 | 04/08/2021 | |
| 21-03-03464-043 | 183.1-73 | 03/08/2021 | ROOM 106 | 3.93 | 04/08/2021 | |
| 21-03-03464-044 | 183.1-74 | 03/08/2021 | GIRLS LOCKER ROOM LEFT | 17.2 | 04/08/2021 | |
| 21-03-03464-045 | 183.1-75 | 03/08/2021 | GIRLS LOCKER ROOM RIGHT | 3.56 | 04/08/2021 | |
| 21-03-03464-046 | 183.1-77 | 03/08/2021 | GIRLS LOCKER ROOM COACHES OFFICE | 65.8 | 04/08/2021 | |
| 21-03-03464-047 | 183.1-79 | 03/08/2021 | BOYS LOCKER ROOM COACHES OFFICE | 14.8 | 04/08/2021 | |
| 21-03-03464-048 | 183.1-81 | 03/08/2021 | BOYS LOCKER ROOM LEFT | 9.00 | 04/08/2021 | |
| 21-03-03464-049 | 183.1-84 | 03/08/2021 | ROOM 112 LAV | 1.09 | 04/08/2021 | |
| 21-03-03464-050 | 183.1-85 | 03/08/2021 | ROOM 112 MAIN | 5.10 | 04/09/2021 | |
| 21-03-03464-051 | 183.1-88 | 03/08/2021 | FRONT GYM HALL LADIES LAV LEFT | 2.79 | 04/08/2021 | |
| 21-03-03464-052 | 183.1-90 | 03/08/2021 | FRONT GYM HALL MENS LAV LEFT | 6.35 | 04/08/2021 | |
| 21-03-03464-053 | 183.1-91 | 03/08/2021 | FRONT GYM HALL MENS LAV RIGHT | 13.0 | 04/08/2021 | |

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03464

Project/Test Address: 2020L-183.1; Forestville Middle/High School; 4 Academy St; Forestville, NY

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|------------------------------------|--------------------------|---------------|--------------|
| 21-03-03464-054 | 183.1-94 | 03/08/2021 | GYM FRONT STORAGE ROOM ICE MACHINE | <1.00 | 04/08/2021 | |

Sample Narratives:

W01: LCS recovery was above the acceptable range. This sample was analyzed using SM3113B.

Method: EPA 200.8
Analyst: Anthony Dee
Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022
Issued April 01, 2021
Revised April 02, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

| | |
|------------------|--|
| Arsenic, Total | EPA 200.8 Rev. 5.4 |
| Copper, Total | SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4 |
| Lead, Total | SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4 |
| Manganese, Total | EPA 200.8 Rev. 5.4 |

NEW YORK
STATE OF
OPPORTUNITY

Department
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody

524



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-183.1

Client: Forestville CSD

Contact: Jim Knoop

Building: Forestville Middle/High School

Location: 4 Academy St. Forestville, NY

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

| Sample # | Location | Outlet Type | Time |
|-----------|--|-------------|-------|
| 183.1-3 | Lunch line room 115 northwest Handwash | S | 22:46 |
| 183.1-4 | Lunch line room 115 East Wall Handwash | S | 22:47 |
| 183.1-5 | Kitchen Center of Room Sink North Side | S | 22:48 |
| 183.1-6 | Kitchen Hand Wash North Wall | S | 22:49 |
| 183.1-7 | Kitchen 3 Bay Sink Left | S | 22:50 |
| 183.1-8 | Kitchen 3 Bay Sink Right | S | 22:51 |
| 183.1-9 | Kitchen Dish Sprayer | S | 22:52 |
| 183.1-10 | Kitchen Steam Pot Right | Steam Pot | 22:53 |
| 183.1-11 | Kitchen Steam Pot Left | Steam Pot | 22:54 |
| 183.1-12 | Kitchen Center of Room Sink South Side | S | 22:55 |
| 183.1-13B | 3rd FLR Drinking Fountain | DFB | 22:56 |
| 183.1-15 | Boys Lav 3rd Floor by 313 | S | 22:57 |
| 183.1-16 | Room 313 Left | S | 22:58 |
| 183.1-17 | Room 313 Right | S | 22:59 |
| 183.1-26 | Girls Lav by 304 Left | S | 23:00 |
| 183.1-27 | Girls Lav by 304 Right | S | 23:01 |
| 183.1-34 | Room 306 Left | S | 23:02 |
| 183.1-35 | Room 306 Right | S | 23:03 |

21-03-03464



Due Date:
 04/13/2021
 (Tuesday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Stohl Env: Christine Schultz Date: 3/8/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/10/2021

Received (Name / Lab): K. HARRIS K. HARRIS Date: 3-16-21 Time: 3:56 pm

Sample Login (Name / Lab): K. HARRIS Date: 4.9.21 Time: 2:00pm

Analysis (Name / Lab): Mary Dice Date: 4/8/21 Time: 8:29pm

QA/QC Review (Name / Lab): Melanie Date: 4/12/21 Time: 5pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-183.1

Client: Forestville CSD Contact: Jim Knoop

Building: Forestville Middle/High School Location: 4 Academy St. Forestville, NY

| | | |
|--|----------|-------------------|
| LEAD | | <i>Turnaround</i> |
| Water by SM 19, 21 - 23 3113B (-04, -10) | <u>X</u> | <u>20 Days</u> |

| Sample # | Location | Outlet Type | Time |
|-----------|----------------------------------|-------------|-------|
| 183.1-37 | 3rd Floor Female Staff Lav Left | S | 23:04 |
| 183.1-38 | 3rd Floor Female Staff Lav Right | S | 23:05 |
| 183.1-41 | 2nd Floor Boys Lav Left | S | 23:06 |
| 183.1-42 | 2nd Floor Boys Lav Right | S | 23:07 |
| 183.1-43B | Drinking Fountain by 202 | DFB | 23:08 |
| 183.1-44 | 2nd Floor Girls Lav Left | S | 23:09 |
| 183.1-45 | 2nd Floor Girls Lav Right | S | 23:10 |
| 183.1-51 | 2nd Floor Male Staff Lav Left | S | 23:11 |
| 183.1-52 | 2nd Floor Male Staff Lav Right | S | 23:12 |
| 183.1-54 | Room 204 | S | 23:13 |
| 183.1-55 | Room 205 North | S | 23:14 |
| 183.1-56 | Room 205 South | S | 23:15 |
| 183.1-57 | Universal Lav Outside 101 | S | 23:16 |
| 183.1-58B | Drinking Fountain Outside 103 | DF | 23:17 |
| 183.1-59 | Universal Restroom Outside 103 | S | 23:18 |
| 183.1-60 | Room 103 | S | 23:19 |
| 183.1-61 | Nurse Room 118 Lav | S | 23:20 |
| 183.1-62 | Nurse Room 118 Exam | S | 23:21 |

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/8/2021

Relinquished By: E. Henderson Jr Print Name Stohl Env: Eric Henderson Jr. Date: 3/10/2021

Received (Name / Lab): KTHARRIS Date: 3.16.21 Time: 3:56 pm

Sample Login (Name / Lab): K. Harris Date: 4.9.21 Time: 2:00 pm

Analysis (Name / Lab): Yang, Oed Date: 4/12/21 Time: 8:29 pm

QA/QC Review (Name / Lab): M. Harris Date: 4/14/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-183.1

Client: Forestville CSD

Contact: Jim Knoop

Building: Forestville Middle/High School

Location: 4 Academy St. Forestville, NY

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

| Sample # | Location | Outlet Type | Time |
|----------|------------------------------------|-------------|-------|
| 183.1-63 | Room 116 | S | 23:22 |
| 183.1-64 | Room 116 Men's Lav | S | 23:23 |
| 183.1-65 | Room 116 Ladies Lav | S | 23:24 |
| 183.1-70 | Women's Lav 115 Right | S | 23:25 |
| 183.1-71 | Men's Lav 114 Left | S | 23:26 |
| 183.1-72 | Men's Lav 114 Right | S | 23:27 |
| 183.1-73 | Room 106 | S | 23:28 |
| 183.1-74 | Girls Locker Room Left | S | 23:29 |
| 183.1-75 | Girls Locker Room Right | S | 23:30 |
| 183.1-77 | Girls Locker Room Coaches Office | S | 23:31 |
| 183.1-79 | Boys Locker Room Coaches Office | S | 23:32 |
| 183.1-81 | Boys Locker Room Left | S | 23:33 |
| 183.1-84 | Room 112 Lav | S | 23:34 |
| 183.1-85 | Room 112 Main | S | 23:35 |
| 183.1-88 | Front Gym Hall Ladies Lav Left | S | 23:36 |
| 183.1-90 | Front Gym Hall Mens Lav Left | S | 23:37 |
| 183.1-91 | Front Gym Hall Mens Lav Right | S | 23:38 |
| 183.1-94 | Gym Front Storage Room Ice Machine | IM | 23:39 |

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/8/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/10/2021

Received (Name / Lab): KT HARRIS Date: 3-16-21 Time: 3:50 pm

Sample Login (Name / Lab): K. Olaves Date: 4.9.21 Time: 2:00 pm

Analysis (Name / Lab): Yang Ocal Date: 4/12/21 Time: 1:29 pm

QA/QC Review (Name / Lab): Meluh Date: 4/12/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

BLANK

BLANK

The logo for Stohl Environmental features the word "Stohl" in a large, bold, green sans-serif font. A white swoosh underline is positioned beneath the "S" and "t". Below "Stohl", the word "ENVIRONMENTAL" is written in a smaller, grey, all-caps sans-serif font.

Stohl
ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM