

October 7, 2025

Mr. Kyle Barthel  
Forestville CSD  
4 Academy St  
Forestville, NY 14062

**Re: Lead Testing in School Drinking Water**

Dear Mr. Barthel:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Forestville Central School District, including:

- Forestville MS/HS – 4 Academy St., Forestville, NY 14062

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on September 13, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 22 sources of potable water in the Middle School/High School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Forestville Central School District.

Sincerely,  
Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Forestville Central School District**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of 9/13/2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Forestville Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Forestville MS/HS – 4 Academy St., Forestville, NY 14062

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Middle School/High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Summary of Samples Collected at Middle School/High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Forestville MS/HS	9/15/2025	63	41	22

\*NYS Action Level is 5 parts per billion

### Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
157.1-02	Lunch Line 115 East Wall Hand Wash	Sink	22.1
157.1-03	Kitchen Center of Room Sink North Side	Sink	6.0
157.1-04	Kitchen Hand Wash North Wall	Sink	11.8
157.1-06	Kitchen 3 Bay Sink Right	Sink	18.5
157.1-07	Kitchen Dish Sprayer	Sink	12.4
157.1-09	Women's Lav 115 Right	Sink	6.1
157.1-10	Women's Lav Left	Sink	10.3
157.1-12	Men's Lav 114 Right	Sink	12.8
157.1-16	Girls Locker Room Left Sink	Sink	14.6
157.1-18	Girls Locker Room Coaches Office	Sink	60.7
157.1-21	Boys Locker Room Sink	Sink	7.1
157.1-22	Front Gym Hall Ladies Lav Left Sink	Sink	6.9
157.1-25	Front Gym Hall Men's Lav Right	Sink	6.2
157.1-29	Room 116 Men's Lav	Sink	9.3
157.1-30	Room 116 Ladies' Lav	Sink	6.7
157.1-31	Nurse Room 118 Lav	Sink	8.6
157.1-34	Room 103	Sink	25.2
157.1-37	2nd Floor Male Staff Lav Left	Sink	8.6
157.1-39	203 Sink	Sink	10.8
157.1-55	Room 306 Left	Sink	132
157.1-56	Room 306 Right	Sink	59.4
157.1-57	3rd Floor Female Staff Lav Left	Sink	11.3

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

#### 1.4 Laboratory Analytical Reports and Chain of Custody Documents



September 30, 2025

Service Request No:R2511650

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

## Laboratory Results for: Forestville MS/HS

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory September 16, 2025  
For your reference, these analyses have been assigned our service request number **R2511650**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.  
dba ALS Environmental





## Narrative Documents

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Forestville MS/HS  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Received:** 09/16/2025

#### CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

#### Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 09/16/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

#### Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read "Meghan Pedicini".

Date

09/30/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.1-01		Lab ID: R2511650-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8
CLIENT ID: 157.1-02		Lab ID: R2511650-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	22.1			1.0	ug/L	200.8
CLIENT ID: 157.1-03		Lab ID: R2511650-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.0			1.0	ug/L	200.8
CLIENT ID: 157.1-04		Lab ID: R2511650-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	11.8			1.0	ug/L	200.8
CLIENT ID: 157.1-05		Lab ID: R2511650-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8
CLIENT ID: 157.1-06		Lab ID: R2511650-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	18.5			1.0	ug/L	200.8
CLIENT ID: 157.1-07		Lab ID: R2511650-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.4			1.0	ug/L	200.8
CLIENT ID: 157.1-08		Lab ID: R2511650-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8
CLIENT ID: 157.1-09		Lab ID: R2511650-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.1			1.0	ug/L	200.8
CLIENT ID: 157.1-10		Lab ID: R2511650-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.3			1.0	ug/L	200.8
CLIENT ID: 157.1-11		Lab ID: R2511650-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.2			1.0	ug/L	200.8
CLIENT ID: 157.1-12		Lab ID: R2511650-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.8			1.0	ug/L	200.8



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.1-15		Lab ID: R2511650-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8
CLIENT ID: 157.1-16		Lab ID: R2511650-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	14.6			1.0	ug/L	200.8
CLIENT ID: 157.1-17		Lab ID: R2511650-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.5			1.0	ug/L	200.8
CLIENT ID: 157.1-18		Lab ID: R2511650-018				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	60.7			1.0	ug/L	200.8
CLIENT ID: 157.1-21		Lab ID: R2511650-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.1			1.0	ug/L	200.8
CLIENT ID: 157.1-22		Lab ID: R2511650-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.9			1.0	ug/L	200.8
CLIENT ID: 157.1-23		Lab ID: R2511650-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.2			1.0	ug/L	200.8
CLIENT ID: 157.1-24		Lab ID: R2511650-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8
CLIENT ID: 157.1-25		Lab ID: R2511650-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.2			1.0	ug/L	200.8
CLIENT ID: 157.1-28		Lab ID: R2511650-029				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8
CLIENT ID: 157.1-29		Lab ID: R2511650-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.3			1.0	ug/L	200.8
CLIENT ID: 157.1-30		Lab ID: R2511650-031				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.7			1.0	ug/L	200.8



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 157.1-31</b>			<b>Lab ID: R2511650-032</b>			
----------------------------	--	--	-----------------------------	--	--	--

<b>Analyte</b>	<b>Results</b>	<b>Flag</b>	<b>MDL</b>	<b>MRL</b>	<b>Units</b>	<b>Method</b>
Lead, Total	8.6			1.0	ug/L	200.8

<b>CLIENT ID: 157.1-32</b>			<b>Lab ID: R2511650-033</b>			
----------------------------	--	--	-----------------------------	--	--	--

<b>Analyte</b>	<b>Results</b>	<b>Flag</b>	<b>MDL</b>	<b>MRL</b>	<b>Units</b>	<b>Method</b>
Lead, Total	3.2			1.0	ug/L	200.8

<b>CLIENT ID: 157.1-34</b>			<b>Lab ID: R2511650-035</b>			
----------------------------	--	--	-----------------------------	--	--	--

<b>Analyte</b>	<b>Results</b>	<b>Flag</b>	<b>MDL</b>	<b>MRL</b>	<b>Units</b>	<b>Method</b>
Lead, Total	25.2			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:**R2511650

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2511650-001	157.1-01	9/13/2025	
R2511650-002	157.1-02	9/13/2025	
R2511650-003	157.1-03	9/13/2025	
R2511650-004	157.1-04	9/13/2025	
R2511650-005	157.1-05	9/13/2025	
R2511650-006	157.1-06	9/13/2025	
R2511650-007	157.1-07	9/13/2025	
R2511650-008	157.1-08	9/13/2025	
R2511650-009	157.1-09	9/13/2025	
R2511650-010	157.1-10	9/13/2025	
R2511650-011	157.1-11	9/13/2025	
R2511650-012	157.1-12	9/13/2025	
R2511650-013	157.1-13A	9/13/2025	
R2511650-014	157.1-14	9/13/2025	
R2511650-015	157.1-15	9/13/2025	
R2511650-016	157.1-16	9/13/2025	
R2511650-017	157.1-17	9/13/2025	
R2511650-018	157.1-18	9/13/2025	
R2511650-019	157.1-19	9/13/2025	
R2511650-020	157.1-20	9/13/2025	
R2511650-021	157.1-21	9/13/2025	
R2511650-022	157.1-22	9/13/2025	
R2511650-023	157.1-23	9/13/2025	
R2511650-024	157.1-24	9/13/2025	
R2511650-025	157.1-25	9/13/2025	
R2511650-026	157.1-26A	9/13/2025	
R2511650-027	157.1-26B	9/13/2025	
R2511650-028	157.1-27	9/13/2025	
R2511650-029	157.1-28	9/13/2025	
R2511650-030	157.1-29	9/13/2025	
R2511650-031	157.1-30	9/13/2025	
R2511650-032	157.1-31	9/13/2025	
R2511650-033	157.1-32	9/13/2025	
R2511650-034	157.1-33	9/13/2025	
R2511650-035	157.1-34	9/13/2025	
R2511650-036	157.1-35A	9/13/2025	



## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name)

ALS

STOHL Job #

2023L-157

Client: Lead in Water

Contact: Mr. Kyle Barthel

Building: Forestville MS/HS

Location: 4 Academy St, Forestville, NY 14062

### LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.1-01	Lunch Line 115 Northwest Hand Wash	Sink	7:15
157.1-02	Lunch Line 115 East Wall Hand Wash	Sink	7:16
157.1-03	Kitchen Center of Room Sink North Side	Sink	7:17
157.1-04	Kitchen Hand Wash North Wall	Sink	7:18
157.1-05	Kitchen 3 Bay Sink Left	Sink	7:19
157.1-06	Kitchen 3 Bay Sink Right	Sink	7:20
157.1-07	Kitchen Dish Sprayer	Sink	7:21
157.1-08	Kitchen Center of Room Sink South Side	Sink	7:22
157.1-09	Women's Lav 115 Right	Sink	7:23
157.1-10	Women's Lav Left	Sink	7:24
157.1-11	Men's Lav 114 Left	Sink	7:25
157.1-12	Men's Lav 114 Right	Sink	7:26
157.1-13A	Outside 114 Lav Bottle Fill Left	Bottle Fill	7:27
157.1-14	Outside 114 Fountain Right	Fountain	7:28
157.1-15	Room 106	Sink	7:29
157.1-16	Girls Locker Room Left Sink	Sink	7:30
157.1-17	Girls Locker Room Right Sink	Sink	7:31
157.1-18	Girls Locker Room Coaches Office	Sink	7:32

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

☒ If checked, also e-mail results to:

[Rfranoine@stohlenvironmental.com](mailto:Rfranoine@stohlenvironmental.com)

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By: \_\_\_\_\_ Print Name Stohl Env: Connor Crilly Date: 9/15/2025

Received (Name / Lab): Thomas Potter Date: 9/16/25 04:18 08:45 Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: 10.9/14/25 Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

**R2511650**

Stohl Environmental  
Forestville MS/HS

**5**







## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-157

Client: Lead in Water Contact: Mr. Kyle Barthel

Building: Forestville MS/HS Location: 4 Academy St, Forestville, NY 14062

### LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.1-19	Girls Locker Room / Gym Bottle Fill	Bottle Fill	7:33
157.1-20	Boys Locker Room / Gym Bottle Fill	Bottle Fill	7:34
157.1-21	Boys Locker Room Sink	Sink	7:35
157.1-22	Front Gym Hall Ladies Lav Left Sink	Sink	7:36
157.1-23	Front Gym Hall Ladies Lav Right Sink	Sink	7:37
157.1-24	Front Gym Hall Men's Lav Left	Sink	7:38
157.1-25	Front Gym Hall Men's Lav Right	Sink	7:39
157.1-26A	Front Gym Hall Bottle Fill	Bottle Fill	7:40
157.1-26B	Front Gym Hall Fountain	Fountain	7:41
157.1-27	Gym Front Storage Room Ice Machine	Ice Machine	7:42
157.1-28	Room 116	Sink	7:43
157.1-29	Room 116 Men's Lav	Sink	7:44
157.1-30	Room 116 Ladies' Lav	Sink	7:45
157.1-31	Nurse Room 118 Lav	Sink	7:46
157.1-32	Nurse Room 118 Exam	Sink	7:47
157.1-33	Universal Restroom Outside 103	Sink	7:48
157.1-34	Room 103	Sink	7:49
157.1-35A	Bottle Fill Outside 103	Bottle Fill	7:50

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

[Rfranoioine@stohlenvironmental.com](mailto:Rfranoioine@stohlenvironmental.com)

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By:                      Print Name Stohl Env: Connor Crilly Date: 9/15/2025

Received (Name / Lab): Thomas Butler Date: 9/16/25 ~~09/18/25~~ Time:                     

Sample Login (Name / Lab):                      Date: 12/9/16/25 Time:                     

Analysis (Name / Lab):                      Date:                      Time:                     

QA/QC Review (Name / Lab):                      Date:                      Time:                     

Archived / Released:                      QA/QC InterLAB Use:                      Date:                      Time:



# Cooler Receipt and Preservation Check Form

R2511650

Stahl Environmental  
Forestville MS/HS

5



Project/Client \_\_\_\_\_ Folder Number \_\_\_\_\_

Cooler received on 9/16/25 by: KRP

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>	5a	Did VOA vials have sig* bubbles?	Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>	5b	Sig* bubbles: Alk? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>	Sulfide? Y <input type="radio"/> N <input checked="" type="radio"/> NA <input type="radio"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>	6	Where did the bottles originate?	ALS/ROC CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>	7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="radio"/> NA <input type="radio"/>

8. Temperature Readings Date: 9/16/25 Time: 845 ID: IR#12 ☒ IR#17 From: Temp Blank Sample Bottle

Temp (°C)	16.1						
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>
If <0°C, were samples frozen?	Y <input type="radio"/> N <input checked="" type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>	Y <input type="radio"/> N <input type="radio"/>

If out of Temperature, note packing/ice condition: metals Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by KRP on 9/16 at 847  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y ☐ N ☐

Cooler Breakdown/Preservation Check\*\*: Date: 9/16/25 Time: 1130 by: TOP

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES ☒ NO ☐  
 10. Did all bottle labels and tags agree with custody papers? YES ☒ NO ☐  
 11. Were correct containers used for the tests indicated? YES ☒ NO ☐  
 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES ☒ NO ☐  
 13. Were dissolved metals filtered in the field? YES ☒ NO ☐  
 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated ☒ N/A ☐

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO <sub>3</sub>	<input checked="" type="checkbox"/>				all	4mL	242587	42
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).\*

Bottle lot numbers: 062325-2ADD

Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TOP

\*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-01  
**Lab Code:** R2511650-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-02  
**Lab Code:** R2511650-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-03  
**Lab Code:** R2511650-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-04  
**Lab Code:** R2511650-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-05  
**Lab Code:** R2511650-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-06  
**Lab Code:** R2511650-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-07  
**Lab Code:** R2511650-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-08  
**Lab Code:** R2511650-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-09  
**Lab Code:** R2511650-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-10  
**Lab Code:** R2511650-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-11  
**Lab Code:** R2511650-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-12  
**Lab Code:** R2511650-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-13A  
**Lab Code:** R2511650-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-14  
**Lab Code:** R2511650-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-15  
**Lab Code:** R2511650-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-16  
**Lab Code:** R2511650-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-17  
**Lab Code:** R2511650-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-18  
**Lab Code:** R2511650-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-19  
**Lab Code:** R2511650-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-20  
**Lab Code:** R2511650-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-21  
**Lab Code:** R2511650-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-22  
**Lab Code:** R2511650-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-23  
**Lab Code:** R2511650-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-24  
**Lab Code:** R2511650-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-25  
**Lab Code:** R2511650-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-26A  
**Lab Code:** R2511650-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-26B  
**Lab Code:** R2511650-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-27  
**Lab Code:** R2511650-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-28  
**Lab Code:** R2511650-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-29  
**Lab Code:** R2511650-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-30  
**Lab Code:** R2511650-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-31  
**Lab Code:** R2511650-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-32  
**Lab Code:** R2511650-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-33  
**Lab Code:** R2511650-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-34  
**Lab Code:** R2511650-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

**dba ALS Environmental**

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511650

**Sample Name:** 157.1-35A  
**Lab Code:** R2511650-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25

**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



## Sample Results

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## Metals

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-01  
**Lab Code:** R2511650-001

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	09/26/25 13:20	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-02  
**Lab Code:** R2511650-002

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	22.1	ug/L	1.0	1	09/26/25 13:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-03  
**Lab Code:** R2511650-003

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.0	ug/L	1.0	1	09/26/25 13:32	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-04  
**Lab Code:** R2511650-004

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.8	ug/L	1.0	1	09/26/25 13:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-05  
**Lab Code:** R2511650-005

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	09/26/25 13:38	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-06  
**Lab Code:** R2511650-006

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.5	ug/L	1.0	1	09/26/25 13:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-07  
**Lab Code:** R2511650-007

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.4	ug/L	1.0	1	09/26/25 13:41	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-08  
**Lab Code:** R2511650-008

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	09/26/25 13:43	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-09  
**Lab Code:** R2511650-009

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.1	ug/L	1.0	1	09/26/25 13:48	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-10  
**Lab Code:** R2511650-010

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.3	ug/L	1.0	1	09/26/25 13:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-11  
**Lab Code:** R2511650-011

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.2	ug/L	1.0	1	09/26/25 13:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-12  
**Lab Code:** R2511650-012

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.8	ug/L	1.0	1	09/26/25 13:52	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-13A  
**Lab Code:** R2511650-013

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 13:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-14  
**Lab Code:** R2511650-014

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 13:55	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-15  
**Lab Code:** R2511650-015

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	09/26/25 13:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-16  
**Lab Code:** R2511650-016

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.6	ug/L	1.0	1	09/26/25 13:58	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-17  
**Lab Code:** R2511650-017

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.5	ug/L	1.0	1	09/26/25 14:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-18  
**Lab Code:** R2511650-018

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	60.7	ug/L	1.0	1	09/26/25 14:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-19  
**Lab Code:** R2511650-019

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-20  
**Lab Code:** R2511650-020

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-21  
**Lab Code:** R2511650-021

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.1	ug/L	1.0	1	09/26/25 14:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-22  
**Lab Code:** R2511650-022

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.9	ug/L	1.0	1	09/26/25 14:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-23  
**Lab Code:** R2511650-023

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.2	ug/L	1.0	1	09/26/25 14:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-24  
**Lab Code:** R2511650-024

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	09/26/25 14:26	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-25  
**Lab Code:** R2511650-025

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.2	ug/L	1.0	1	09/26/25 14:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-26A  
**Lab Code:** R2511650-026

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:29	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-26B  
**Lab Code:** R2511650-027

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-27  
**Lab Code:** R2511650-028

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:32	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-28  
**Lab Code:** R2511650-029

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	09/26/25 14:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-29  
**Lab Code:** R2511650-030

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.3	ug/L	1.0	1	09/26/25 14:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-30  
**Lab Code:** R2511650-031

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.7	ug/L	1.0	1	09/26/25 14:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-31  
**Lab Code:** R2511650-032

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.6	ug/L	1.0	1	09/26/25 14:42	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-32  
**Lab Code:** R2511650-033

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.2	ug/L	1.0	1	09/26/25 14:43	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-33  
**Lab Code:** R2511650-034

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-34  
**Lab Code:** R2511650-035

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	25.2	ug/L	1.0	1	09/26/25 14:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-35A  
**Lab Code:** R2511650-036

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:48	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## Metals

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2511650-MB1

**Service Request:** R2511650  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 14:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2511650-MB2

**Service Request:** R2511650  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 13:29	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2511650-MB3

**Service Request:** R2511650  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/26/25 12:40	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25  
**Date Analyzed:** 09/26/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** 157.1-02  
**Lab Code:** R2511650-002  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Matrix Spike					Duplicate Matrix Spike				
	R2511650-002MS					R2511650-002DMS				
	Sample Result	Result	Spike Amount	% Rec	Result	Spike Amount	% Rec	% Rec Limits	RPD	RPD Limit
Lead, Total	22.1	43.1	20.0	105	43.6	20.0	108	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25  
**Date Analyzed:** 09/26/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** 157.1-03  
**Lab Code:** R2511650-003  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2511650-003MS		Result	Duplicate Matrix Spike R2511650-003DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	6.0	25.7	20.0	98	26.0	20.0	100	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25  
**Date Analyzed:** 09/26/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** 157.1-22  
**Lab Code:** R2511650-022  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Matrix Spike R2511650-022MS				Duplicate Matrix Spike R2511650-022DMS				RPD Limit
		Result	Spike Amount	% Rec	Result	Spike Amount	% Rec	% Rec Limits	RPD	
Lead, Total	6.9	27.0	20.0	100	27.4	20.0	102	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25  
**Date Analyzed:** 09/26/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** 157.1-23  
**Lab Code:** R2511650-023  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2511650-023MS		Result	Duplicate Matrix Spike R2511650-023DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	4.2	24.6	20.0	102	24.4	20.0	101	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Analyzed:** 09/26/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2511650-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511650  
**Date Analyzed:** 09/26/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2511650-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	104	85-115

Client: Stohl Environmental  
Project: Forestville MS/HS/2023L-157  
Sample Matrix: Drinking Water

Service Request: R2511650  
Date Analyzed: 09/26/25

Lab Control Sample Summary  
Inorganic Parameters

Units:ug/L  
Basis:NA

Lab Control Sample  
R2511650-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.0	20.0	105	85-115





September 22, 2025

Service Request No:R2511651

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

## Laboratory Results for: Forestville MS/HS

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory September 16, 2025  
For your reference, these analyses have been assigned our service request number **R2511651**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.  
dba ALS Environmental



## Narrative Documents

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Forestville MS/HS  
**Sample Matrix:** Drinking Water

**Service Request:** R2511651  
**Date Received:** 09/16/2025

#### CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

#### Sample Receipt:

Twenty seven drinking water samples were received for analysis at ALS Environmental on 09/16/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

#### Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro

Date 09/22/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.1-36		Lab ID: R2511651-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.3			1.0	ug/L	200.8
CLIENT ID: 157.1-37		Lab ID: R2511651-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.6			1.0	ug/L	200.8
CLIENT ID: 157.1-38		Lab ID: R2511651-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8
CLIENT ID: 157.1-39		Lab ID: R2511651-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.8			1.0	ug/L	200.8
CLIENT ID: 157.1-40		Lab ID: R2511651-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8
CLIENT ID: 157.1-41		Lab ID: R2511651-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8
CLIENT ID: 157.1-43		Lab ID: R2511651-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.1			1.0	ug/L	200.8
CLIENT ID: 157.1-47		Lab ID: R2511651-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8
CLIENT ID: 157.1-50		Lab ID: R2511651-019				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.5			1.0	ug/L	200.8
CLIENT ID: 157.1-51		Lab ID: R2511651-020				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8
CLIENT ID: 157.1-54		Lab ID: R2511651-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.5			1.0	ug/L	200.8
CLIENT ID: 157.1-55		Lab ID: R2511651-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	132			1.0	ug/L	200.8



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.1-56			Lab ID: R2511651-025			
---------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	59.4			1.0	ug/L	200.8

CLIENT ID: 157.1-57			Lab ID: R2511651-026			
---------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	11.3			1.0	ug/L	200.8

CLIENT ID: 157.1-58			Lab ID: R2511651-027			
---------------------	--	--	----------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:**R2511651

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2511651-001	157.1-35B	9/13/2025	
R2511651-002	157.1-36	9/13/2025	
R2511651-003	157.1-37	9/13/2025	
R2511651-004	157.1-38	9/13/2025	
R2511651-005	157.1-39	9/13/2025	
R2511651-006	157.1-40	9/13/2025	
R2511651-007	157.1-41	9/13/2025	
R2511651-008	157.1-42A	9/13/2025	
R2511651-009	157.1-42B	9/13/2025	
R2511651-010	157.1-43	9/13/2025	
R2511651-011	157.1-44	9/13/2025	
R2511651-012	157.1-45A	9/13/2025	
R2511651-013	157.1-45B	9/13/2025	
R2511651-015	157.1-47	9/13/2025	
R2511651-016	157.1-48A	9/13/2025	
R2511651-017	157.1-48B	9/13/2025	
R2511651-018	157.1-49	9/13/2025	
R2511651-019	157.1-50	9/13/2025	
R2511651-020	157.1-51	9/13/2025	
R2511651-021	157.1-52	9/13/2025	
R2511651-022	157.1-53	9/13/2025	
R2511651-023	157.1-54	9/13/2025	
R2511651-024	157.1-55	9/13/2025	
R2511651-025	157.1-56	9/13/2025	
R2511651-026	157.1-57	9/13/2025	
R2511651-027	157.1-58	9/13/2025	



## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-157

Client: Lead in Water Contact: Mr. Kyle Barthel

Building: Forestville MS/HS Location: 4 Academy St, Forestville, NY 14062

### LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.1-35B	Fountain Outside 103	Fountain	7:51
157.1-36	Universal Lav Outside 101	Sink	7:52
157.1-37	2nd Floor Male Staff Lav Left	Sink	7:53
157.1-38	2nd Floor Male Staff Lav Right	Sink	7:54
157.1-39	203 Sink	Sink	7:55
157.1-40	2nd Floor Boys Lav Left	Sink	7:56
157.1-41	2nd Floor Boys Lav Right	Sink	7:57
157.1-42A	Outside 202 Bottle Fill	Bottle Fill	7:58
157.1-42B	Outside 202 Fountain	Fountain	7:59
157.1-43	2nd Floor Girls Lav Left	Sink	8:00
157.1-44	2nd Floor Girls Lav Right	Sink	8:01
157.1-45A	Outside 210 Bottle Fill	Bottle Fill	8:02
157.1-45B	Outside 210 Fountain	Fountain	8:03
157.1-46	3rd Floor Men's Lav Left Sink	Sink	8:04
157.1-47	3rd Floor Men's Lav Right Sink	Sink	8:05
157.1-48A	Outside 313 Bottle Fill	Bottle Fill	8:06
157.1-48B	Outside 313 Fountain	Fountain	8:07
157.1-49	Room 313 Left	Sink	8:08

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

[Rfranjioine@stohlenvironmental.com](mailto:Rfranjioine@stohlenvironmental.com)

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By: \_\_\_\_\_ Print Name Stohl Env: Connor Crilly Date: 9/15/2025


Received (Name / Lab): Thomas Potter Date: 9/16/25 09:18 08:45 Time: \_\_\_\_\_

Sample Login (Name / Lab): \_\_\_\_\_ Date: 9/16/25 Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_









## Cooler Receipt and Preservation Check Form

R2511651

Stahl Environmental  
Forestville MS/HS

5

Project/Client

Folder Number

Cooler received on 9/16/25

by: RJP

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> MA
5b	Sig* bubbles: Alk? Y N <input checked="" type="radio"/> MA Sulfide? Y N <input checked="" type="radio"/> MA	
6	Where did the bottles originate?	ALS/ROC CLIENT
7	Soil VOA received as: Bulk Encore 5035set	NA

8. Temperature Readings

Date: 9/16/25

Time: 845

ID: IR#12 (R#1)

From: Temp Blank Sample Bottle

Temp (°C)							
Within 0-6°C?	Y <input checked="" type="radio"/> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: metals Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:

All samples held in storage location: SMO by RJP on 9/16 at 847  
5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 9/16/25 Time: 1248 by: TJP

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO  
10. Did all bottle labels and tags agree with custody papers? YES NO  
11. Were correct containers used for the tests indicated? YES NO  
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A  
13. Were dissolved metals filtered in the field? YES NO N/A  
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?	Lot Received	Exp	Sample ID	Vol. Added	Lot Added	Final pH
			Yes No			Adjusted			
≥12		NaOH							
≤2		HNO <sub>3</sub>	✓			all	4mL	242587	<2
≤2		H <sub>2</sub> SO <sub>4</sub>							
<4		NaHSO <sub>4</sub>							
5-9		For 608pest		No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522		If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>							
		ZnAcetate	- -						
		HCl	** **						

\*\*VOAs and 1664 Not to be tested before analysis.  
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives)."

Bottle lot numbers: 651225-2ADD

Explain all Discrepancies/ Other Comments:

\* 014 not preserved, sample volume insufficient;  
placed on hold unpreserved

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: RJP

\*significant air bubbles: VOA &gt; 5-6 mm : WC &gt; 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511651

**Sample Name:** 157.1-35B  
**Lab Code:** R2511651-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-36  
**Lab Code:** R2511651-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-37  
**Lab Code:** R2511651-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-38  
**Lab Code:** R2511651-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-39  
**Lab Code:** R2511651-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511651

**Sample Name:** 157.1-40  
**Lab Code:** R2511651-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-41  
**Lab Code:** R2511651-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-42A  
**Lab Code:** R2511651-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-42B  
**Lab Code:** R2511651-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-43  
**Lab Code:** R2511651-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511651

**Sample Name:** 157.1-44  
**Lab Code:** R2511651-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-45A  
**Lab Code:** R2511651-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-45B  
**Lab Code:** R2511651-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-47  
**Lab Code:** R2511651-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-48A  
**Lab Code:** R2511651-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511651

**Sample Name:** 157.1-48B  
**Lab Code:** R2511651-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-49  
**Lab Code:** R2511651-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-50  
**Lab Code:** R2511651-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-51  
**Lab Code:** R2511651-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-52  
**Lab Code:** R2511651-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

## Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511651

**Sample Name:** 157.1-53  
**Lab Code:** R2511651-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-54  
**Lab Code:** R2511651-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-55  
**Lab Code:** R2511651-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-56  
**Lab Code:** R2511651-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 157.1-57  
**Lab Code:** R2511651-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

**dba ALS Environmental**

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157

**Service Request:** R2511651

**Sample Name:** 157.1-58  
**Lab Code:** R2511651-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 09/13/25  
**Date Received:** 09/16/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



## Sample Results

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## Metals

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-35B  
**Lab Code:** R2511651-001

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 16:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-36  
**Lab Code:** R2511651-002

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	09/18/25 16:59	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-37  
**Lab Code:** R2511651-003

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.6	ug/L	1.0	1	09/18/25 17:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-38  
**Lab Code:** R2511651-004

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	09/18/25 17:02	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-39  
**Lab Code:** R2511651-005

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.8	ug/L	1.0	1	09/18/25 17:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-40  
**Lab Code:** R2511651-006

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	09/18/25 17:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-41  
**Lab Code:** R2511651-007

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	09/18/25 17:10	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-42A  
**Lab Code:** R2511651-008

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-42B  
**Lab Code:** R2511651-009

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-43  
**Lab Code:** R2511651-010

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	09/18/25 17:27	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-44  
**Lab Code:** R2511651-011

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-45A  
**Lab Code:** R2511651-012

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-45B  
**Lab Code:** R2511651-013

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-47  
**Lab Code:** R2511651-015

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	09/18/25 17:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-48A  
**Lab Code:** R2511651-016

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-48B  
**Lab Code:** R2511651-017

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-49  
**Lab Code:** R2511651-018

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-50  
**Lab Code:** R2511651-019

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	09/18/25 17:42	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-51  
**Lab Code:** R2511651-020

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	09/18/25 17:43	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-52  
**Lab Code:** R2511651-021

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-53  
**Lab Code:** R2511651-022

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-54  
**Lab Code:** R2511651-023

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.5	ug/L	1.0	1	09/18/25 17:48	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-55  
**Lab Code:** R2511651-024

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	132	ug/L	1.0	1	09/18/25 17:50	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-56  
**Lab Code:** R2511651-025

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	59.4	ug/L	1.0	1	09/18/25 17:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-57  
**Lab Code:** R2511651-026

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.3	ug/L	1.0	1	09/18/25 17:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** 157.1-58  
**Lab Code:** R2511651-027

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25 08:45  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	09/18/25 17:57	





## QC Summary Forms

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)



## Metals

**ALS Environmental—Rochester Laboratory**

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2511651-MB1

**Service Request:** R2511651  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 16:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2511651-MB2

**Service Request:** R2511651  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25  
**Date Analyzed:** 09/18/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** 157.1-42A  
**Lab Code:** R2511651-008  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2511651-008MS		Result	Duplicate Matrix Spike R2511651-008DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.3	20.0	96	19.1	20.0	95	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511651  
**Date Collected:** 09/13/25  
**Date Received:** 09/16/25  
**Date Analyzed:** 09/18/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** 157.1-42B  
**Lab Code:** R2511651-009  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2511651-009MS		Result	Duplicate Matrix Spike R2511651-009DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.6	20.0	98	19.5	20.0	97	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental  
Project: Forestville MS/HS/2023L-157  
Sample Matrix: Drinking Water

Service Request: R2511651  
Date Analyzed: 09/18/25

Lab Control Sample Summary  
Inorganic Parameters

Units:ug/L  
Basis:NA

Lab Control Sample  
R2511651-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.9	20.0	100	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Forestville MS/HS/2023L-157  
**Sample Matrix:** Drinking Water

**Service Request:** R2511651  
**Date Analyzed:** 09/18/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA


**Lab Control Sample**  
R2511651-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.3	20.0	101	85-115



## 1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2025  
Issued April 01, 2024

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
ALS ENVIRONMENTAL - ROCHESTER  
1565 JEFFERSON ROAD BUILDING 300, SUITE 360  
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

<b>Bacteriology</b>	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
<b>Disinfection By-products</b>	
Bromide	EPA 300.0 Rev. 2.1
<b>Dissolved Gases</b>	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
<b>Fuel Additives</b>	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
<b>Metals I</b>	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4

Serial No.: 68402

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

Page 1 of 5

