

October 7, 2025

Mr. Kyle Barthel
Forestville CSD
4 Academy St
Forestville, NY 14062

Re: Lead Testing in School Drinking Water

Dear Mr. Barthel:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Forestville Central School District, including:

- Forestville Elementary School – 12 Water St., Forestville, NY 14062

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on September 13, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 58 sources of potable water in the Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Forestville Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Forestville Central School District

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of 9/13/2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Forestville Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- Forestville Elementary School – 12 Water St., Forestville, NY 14062

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Forestville Elementary School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Forestville Elementary School	9/15/2025	78	20	58

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
157.2-05	Classroom 11 Sink	Sink	9.9
157.2-06	Classroom 11 Fountain	Fountain	5.1
157.2-07	Classroom 10 Sink	Sink	6.6
157.2-08	Classroom 10 Fountain	Fountain	5.2
157.2-09	Classroom 9 Sink	Sink	6.8
157.2-11	Classroom 8 Sink	Sink	8
157.2-14	Classroom 6 Staff Lounge Fountain	Fountain	8.9
157.2-15	Business Office Sink	Sink	9.8
157.2-16	Girls Bathroom 14 - West Sink	Sink	13.5
157.2-17	Girls Bathroom 14 - East Sink	Sink	7.3
157.2-18	Boys Bathroom 15 - West Sink	Sink	9.7
157.2-19	Boys Bathroom 15 - East Sink	Sink	22.6
157.2-20	Staff Bathroom 3A	Sink	21.3
157.2-21	Psychology Room Sink	Sink	11
157.2-22	Kitchen Dish Sink	Sink	8.3
157.2-23	Kitchen Bathroom Sink	Sink	8.9
157.2-24	Kitchen Deep Sink	Sink	25
157.2-26	Kitchen Steam Pot	Steam Pot	138
157.2-27	Nurse Bathroom Sink	Sink	10.2
157.2-28	Nurse Exam Sink	Sink	5.8
157.2-30	Girls Locker Room Sink	Sink	18.8
157.2-31	Boys Locker Room Sink	Sink	13.3
157.2-32	Classroom 25 Sink	Sink	6.2
157.2-33	Classroom 25 Fountain	Fountain	21.3

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
157.2-34	Classroom 25 Bathroom Sink	Sink	5.6
157.2-35	Classroom 24 Sink	Sink	20.2
157.2-36	Classroom 24 Fountain	Fountain	6.4
157.2-37	Classroom 24 Bathroom Sink	Sink	10.7
157.2-38	Classroom 27 Sink	Sink	13.3
157.2-40	Classroom 27 Bathroom Sink	Sink	8.3
157.2-43	Classroom 26 Bathroom Sink	Sink	25.2
157.2-46	Classroom 29 Bathroom Sink	Sink	6.6
157.2-47	Classroom 28 Sink	Sink	5.5
157.2-49	Classroom 28 Bathroom Sink	Sink	18.3
157.2-50	Classroom 31 Steel Sink	Sink	6.1
157.2-52	Classroom 31 White Sink	Sink	10.3
157.2-53	Classroom 30 Steel Sink	Sink	12.8
157.2-55	Classroom 30 White Sink	Sink	21.8
157.2-56	Classroom 33 Steel Sink	Sink	7.8
157.2-57	Classroom 33 Fountain	Sink	5.9
157.2-58	Classroom 33 White Sink	Sink	36.9
157.2-59	Classroom 32 Steel Sink	Sink	236
157.2-60	Classroom 32 Fountain	Sink	11.4
157.2-61	Classroom 32 White Sink	Sink	26.6
157.2-63	Classroom 34 Steel Sink	Sink	13.9
157.2-64	Classroom 34 Fountain	Fountain	28.1
157.2-65	Classroom 36 Sink	Sink	16.4
157.2-66	Classroom 36 Fountain	Fountain	9.9
157.2-67	Classroom 40 Steel Sink	Sink	18.9
157.2-68	Classroom 40 Fountain	Fountain	7.3
157.2-69	Classroom 39 Sink	Sink	7.8
157.2-70	Classroom 39 Fountain	Fountain	17.7
157.2-72	Classroom 44 Fountain	Fountain	14.6
157.2-73	Classroom 41 Sink	Sink	8.6
157.2-74	Classroom 41 Fountain	Fountain	32.2
157.2-75	Classroom 46 Sink	Sink	19.9
157.2-77	Women's Staff Lav Sink	Sink	23.7
157.2-78	Men's Staff Lav Sink	Sink	13.3

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



September 22, 2025

Service Request No:R2511648

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Forestville ES

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory September 16, 2025
For your reference, these analyses have been assigned our service request number **R2511648**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Forestville ES
Sample Matrix: Drinking Water

Service Request: R2511648
Date Received: 09/16/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 09/16/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read "Meghan Pedicini".

Date

09/22/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-01		Lab ID: R2511648-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.7			1.0	ug/L	200.8
CLIENT ID: 157.2-03		Lab ID: R2511648-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.8			1.0	ug/L	200.8
CLIENT ID: 157.2-04		Lab ID: R2511648-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8
CLIENT ID: 157.2-05		Lab ID: R2511648-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.9			1.0	ug/L	200.8
CLIENT ID: 157.2-06		Lab ID: R2511648-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.1			1.0	ug/L	200.8
CLIENT ID: 157.2-07		Lab ID: R2511648-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.6			1.0	ug/L	200.8
CLIENT ID: 157.2-08		Lab ID: R2511648-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.2			1.0	ug/L	200.8
CLIENT ID: 157.2-09		Lab ID: R2511648-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.8			1.0	ug/L	200.8
CLIENT ID: 157.2-10		Lab ID: R2511648-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8
CLIENT ID: 157.2-11		Lab ID: R2511648-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.0			1.0	ug/L	200.8
CLIENT ID: 157.2-12		Lab ID: R2511648-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.1			1.0	ug/L	200.8
CLIENT ID: 157.2-13		Lab ID: R2511648-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.6			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-14		Lab ID: R2511648-014				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.9			1.0	ug/L	200.8
CLIENT ID: 157.2-15		Lab ID: R2511648-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.8			1.0	ug/L	200.8
CLIENT ID: 157.2-16		Lab ID: R2511648-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.5			1.0	ug/L	200.8
CLIENT ID: 157.2-17		Lab ID: R2511648-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.3			1.0	ug/L	200.8
CLIENT ID: 157.2-18		Lab ID: R2511648-018				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.7			1.0	ug/L	200.8
CLIENT ID: 157.2-19		Lab ID: R2511648-019				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	22.6			1.0	ug/L	200.8
CLIENT ID: 157.2-20		Lab ID: R2511648-020				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	21.3			1.0	ug/L	200.8
CLIENT ID: 157.2-21		Lab ID: R2511648-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	11.0			1.0	ug/L	200.8
CLIENT ID: 157.2-22		Lab ID: R2511648-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.3			1.0	ug/L	200.8
CLIENT ID: 157.2-23		Lab ID: R2511648-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.9			1.0	ug/L	200.8
CLIENT ID: 157.2-24		Lab ID: R2511648-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	25.0			1.0	ug/L	200.8
CLIENT ID: 157.2-26		Lab ID: R2511648-026				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	138			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-27		Lab ID: R2511648-027				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.2			1.0	ug/L	200.8
CLIENT ID: 157.2-28		Lab ID: R2511648-028				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.8			1.0	ug/L	200.8
CLIENT ID: 157.2-30		Lab ID: R2511648-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	18.8			1.0	ug/L	200.8
CLIENT ID: 157.2-31		Lab ID: R2511648-031				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.3			1.0	ug/L	200.8
CLIENT ID: 157.2-32		Lab ID: R2511648-032				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.2			1.0	ug/L	200.8
CLIENT ID: 157.2-33		Lab ID: R2511648-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	21.3			1.0	ug/L	200.8
CLIENT ID: 157.2-34		Lab ID: R2511648-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.6			1.0	ug/L	200.8
CLIENT ID: 157.2-35		Lab ID: R2511648-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	20.2			1.0	ug/L	200.8
CLIENT ID: 157.2-36		Lab ID: R2511648-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request:R2511648

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2511648-001	157.2-01	9/13/2025	
R2511648-002	157.2-02	9/13/2025	
R2511648-003	157.2-03	9/13/2025	
R2511648-004	157.2-04	9/13/2025	
R2511648-005	157.2-05	9/13/2025	
R2511648-006	157.2-06	9/13/2025	
R2511648-007	157.2-07	9/13/2025	
R2511648-008	157.2-08	9/13/2025	
R2511648-009	157.2-09	9/13/2025	
R2511648-010	157.2-10	9/13/2025	
R2511648-011	157.2-11	9/13/2025	
R2511648-012	157.2-12	9/13/2025	
R2511648-013	157.2-13	9/13/2025	
R2511648-014	157.2-14	9/13/2025	
R2511648-015	157.2-15	9/13/2025	
R2511648-016	157.2-16	9/13/2025	
R2511648-017	157.2-17	9/13/2025	
R2511648-018	157.2-18	9/13/2025	
R2511648-019	157.2-19	9/13/2025	
R2511648-020	157.2-20	9/13/2025	
R2511648-021	157.2-21	9/13/2025	
R2511648-022	157.2-22	9/13/2025	
R2511648-023	157.2-23	9/13/2025	
R2511648-024	157.2-24	9/13/2025	
R2511648-025	157.2-25	9/13/2025	
R2511648-026	157.2-26	9/13/2025	
R2511648-027	157.2-27	9/13/2025	
R2511648-028	157.2-28	9/13/2025	
R2511648-029	157.2-29	9/13/2025	
R2511648-030	157.2-30	9/13/2025	
R2511648-031	157.2-31	9/13/2025	
R2511648-032	157.2-32	9/13/2025	
R2511648-033	157.2-33	9/13/2025	
R2511648-034	157.2-34	9/13/2025	
R2511648-035	157.2-35	9/13/2025	
R2511648-036	157.2-36	9/13/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-157

Client: Lead in Water

Contact: Mr. Kyle Barthel

Building: Forestville ES

Location: 12 Water St, Forestville, NY 14062

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.2-01	Classroom 13 South Wall Sink	Sink	9:30
157.2-02	Classroom 13 Fountain	Fountain	9:31
157.2-03	Classroom 12 Sink	Sink	9:32
157.2-04	Classroom 12 Fountain	Fountain	9:33
157.2-05	Classroom 11 Sink	Sink	9:34
157.2-06	Classroom 11 Fountain	Fountain	9:35
157.2-07	Classroom 10 Sink	Sink	9:36
157.2-08	Classroom 10 Fountain	Fountain	9:37
157.2-09	Classroom 9 Sink	Sink	9:38
157.2-10	Classroom 9 Fountain	Fountain	9:39
157.2-11	Classroom 8 Sink	Sink	9:40
157.2-12	Classroom 8 Fountain	Fountain	9:41
157.2-13	Classroom 6 Staff Lounge Sink	Sink	9:42
157.2-14	Classroom 6 Staff Lounge Fountain	Fountain	9:43
157.2-15	Business Office Sink	Sink	9:44
157.2-16	Girls Bathroom 14 - West Sink	Sink	9:45
157.2-17	Girls Bathroom 14 - East Sink	Sink	9:46
157.2-18	Boys Bathroom 15 - West Sink	Sink	9:47

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Rfranjoine@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By: Print Name Stohl Env: Connor Crilly Date: 9/15/2025

Received (Name / Lab): Thomas Potter ALS Date: 9/16/25 Time: 845

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:

R2511648

Stohl Environmental
Forestville ES

5





3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-157

Client: Lead in Water

Contact: Mr. Kyle Barthel

Building: Forestville ES

Location: 12 Water St, Forestville, NY 14062

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.2-19	Boys Bathroom 15 - East Sink	Sink	9:48
157.2-20	Staff Bathroom 3A	Sink	9:49
157.2-21	Psychology Room Sink	Sink	9:50
157.2-22	Kitchen Dish Sink	Sink	9:51
157.2-23	Kitchen Bathroom Sink	Sink	9:52
157.2-24	Kitchen Deep Sink	Sink	9:53
157.2-25	Cafeteria Bottle Fill	Bottle Fill	9:54
157.2-26	Kitchen Steam Pot	Steam Pot	9:55
157.2-27	Nurse Bathroom Sink	Sink	9:56
157.2-28	Nurse Exam Sink	Sink	9:57
157.2-29	Drinking Fountain Hallway Near Gym	Fountain	9:58
157.2-30	Girls Locker Room Sink	Sink	9:59
157.2-31	Boys Locker Room Sink	Sink	10:00
157.2-32	Classroom 25 Sink	Sink	10:01
157.2-33	Classroom 25 Fountain	Fountain	10:02
157.2-34	Classroom 25 Bathroom Sink	Sink	10:03
157.2-35	Classroom 24 Sink	Sink	10:04
157.2-36	Classroom 24 Fountain	Fountain	10:05

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Rfranjone@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By: Print Name Stohl Env: Connor Crilly Date: 9/15/2025

Received (Name / Lab): Thomas Ritter ALS Date: 9/16/25 Time: 845

Sample Login (Name / Lab): Date: Time:

Analysis (Name / Lab): Date: Time:

QA/QC Review (Name / Lab): Date: Time:

Archived / Released: QA/QC InterLAB Use: Date: Time:



Cooler Receipt and Preservation Check Form

R2511648

Stohi Environmental
Forestville ES

5



Project/Client _____ Folder Number _____

Cooler received on 9/16/25 by: KRP

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N	5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 9/16/25 Time: 845 ID: IR#12 IR#1 From: Temp Blank Sample Bottle

Temp (°C)							
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: metals Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by KRP on 9/16 at 847
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 9/16/25 Time: 1324 by: TSP

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO NA
13. Were dissolved metals filtered in the field? YES NO NA
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃	<u>✓</u>				<u>a11</u>	<u>4mL</u>	<u>2412587</u>	<u>6.2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives)."

Bottle lot numbers: 061225-2ADD

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: TSP

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-01
Lab Code: R2511648-001
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-02
Lab Code: R2511648-002
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-03
Lab Code: R2511648-003
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-04
Lab Code: R2511648-004
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-05
Lab Code: R2511648-005
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-06
Lab Code: R2511648-006
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-07
Lab Code: R2511648-007
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-08
Lab Code: R2511648-008
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-09
Lab Code: R2511648-009
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-10
Lab Code: R2511648-010
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-11
Lab Code: R2511648-011
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-12
Lab Code: R2511648-012
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-13
Lab Code: R2511648-013
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-14
Lab Code: R2511648-014
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-15
Lab Code: R2511648-015
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-16
Lab Code: R2511648-016
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-17
Lab Code: R2511648-017
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-18
Lab Code: R2511648-018
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-19
Lab Code: R2511648-019
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-20
Lab Code: R2511648-020
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-21
Lab Code: R2511648-021
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-22
Lab Code: R2511648-022
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-23
Lab Code: R2511648-023
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-24
Lab Code: R2511648-024
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-25
Lab Code: R2511648-025
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-26
Lab Code: R2511648-026
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-27
Lab Code: R2511648-027
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-28
Lab Code: R2511648-028
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-29
Lab Code: R2511648-029
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-30
Lab Code: R2511648-030
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-31
Lab Code: R2511648-031
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-32
Lab Code: R2511648-032
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-33
Lab Code: R2511648-033
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-34
Lab Code: R2511648-034
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-35
Lab Code: R2511648-035
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511648

Sample Name: 157.2-36
Lab Code: R2511648-036
Sample Matrix: Drinking Water

Date Collected: 09/13/25

Date Received: 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-01
Lab Code: R2511648-001

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.7	ug/L	1.0	1	09/18/25 15:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-02
Lab Code: R2511648-002

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 15:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-03
Lab Code: R2511648-003

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.8	ug/L	1.0	1	09/18/25 15:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-04
Lab Code: R2511648-004

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	09/18/25 15:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-05
Lab Code: R2511648-005

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.9	ug/L	1.0	1	09/18/25 15:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-06
Lab Code: R2511648-006

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.1	ug/L	1.0	1	09/18/25 15:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-07
Lab Code: R2511648-007

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.6	ug/L	1.0	1	09/18/25 15:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-08
Lab Code: R2511648-008

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.2	ug/L	1.0	1	09/18/25 15:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-09
Lab Code: R2511648-009

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.8	ug/L	1.0	1	09/18/25 15:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-10
Lab Code: R2511648-010

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	09/18/25 15:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-11
Lab Code: R2511648-011

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.0	ug/L	1.0	1	09/18/25 15:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-12
Lab Code: R2511648-012

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.1	ug/L	1.0	1	09/18/25 16:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-13
Lab Code: R2511648-013

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.6	ug/L	1.0	1	09/18/25 16:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-14
Lab Code: R2511648-014

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.9	ug/L	1.0	1	09/18/25 16:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-15
Lab Code: R2511648-015

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.8	ug/L	1.0	1	09/18/25 16:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-16
Lab Code: R2511648-016

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.5	ug/L	1.0	1	09/18/25 16:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-17
Lab Code: R2511648-017

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.3	ug/L	1.0	1	09/18/25 16:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-18
Lab Code: R2511648-018

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.7	ug/L	1.0	1	09/18/25 16:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-19
Lab Code: R2511648-019

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	22.6	ug/L	1.0	1	09/18/25 16:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-20
Lab Code: R2511648-020

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.3	ug/L	1.0	1	09/18/25 16:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-21
Lab Code: R2511648-021

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.0	ug/L	1.0	1	09/18/25 16:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-22
Lab Code: R2511648-022

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.3	ug/L	1.0	1	09/18/25 16:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-23
Lab Code: R2511648-023

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.9	ug/L	1.0	1	09/18/25 16:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-24
Lab Code: R2511648-024

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	25.0	ug/L	1.0	1	09/18/25 16:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-25
Lab Code: R2511648-025

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 16:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-26
Lab Code: R2511648-026

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	138	ug/L	1.0	1	09/18/25 16:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-27
Lab Code: R2511648-027

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.2	ug/L	1.0	1	09/18/25 16:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-28
Lab Code: R2511648-028

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.8	ug/L	1.0	1	09/18/25 16:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-29
Lab Code: R2511648-029

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 16:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-30
Lab Code: R2511648-030

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.8	ug/L	1.0	1	09/18/25 16:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-31
Lab Code: R2511648-031

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.3	ug/L	1.0	1	09/18/25 16:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-32
Lab Code: R2511648-032

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.2	ug/L	1.0	1	09/18/25 16:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-33
Lab Code: R2511648-033

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.3	ug/L	1.0	1	09/18/25 16:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-34
Lab Code: R2511648-034

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.6	ug/L	1.0	1	09/18/25 16:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-35
Lab Code: R2511648-035

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.2	ug/L	1.0	1	09/18/25 16:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-36
Lab Code: R2511648-036

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.4	ug/L	1.0	1	09/18/25 16:56	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2511648-MB1

Service Request: R2511648
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2511648-MB2

Service Request: R2511648
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 15:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2511648-MB3

Service Request: R2511648
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 16:30	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-04
Lab Code: R2511648-004
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.5	21.0	20.0	98	21.0	20.0	97	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-05
Lab Code: R2511648-005
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	9.9	30.2	20.0	102	30.3	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-24
Lab Code: R2511648-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result		Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	25.0	46.0	20.0	105	45.4	20.0	102	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-25
Lab Code: R2511648-025
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2511648-025MS		Result	Duplicate Matrix Spike R2511648-025DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	18.8	20.0	94	19.5	20.0	98	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648**Date Analyzed:** 09/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L**Basis:**NA**Lab Control Sample**

R2511648-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.2	20.0	101	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648
Date Analyzed: 09/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2511648-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.9	20.0	99	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511648
Date Analyzed: 09/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2511648-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.9	20.0	100	85-115



September 24, 2025

Service Request No:R2511649

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Forestville ES

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory September 16, 2025
For your reference, these analyses have been assigned our service request number **R2511649**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Forestville ES
Sample Matrix: Drinking Water

Service Request: R2511649
Date Received: 09/16/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Forty two drinking water samples were received for analysis at ALS Environmental on 09/16/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro

Date 09/24/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-37		Lab ID: R2511649-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.7			1.0	ug/L	200.8
CLIENT ID: 157.2-38		Lab ID: R2511649-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.3			1.0	ug/L	200.8
CLIENT ID: 157.2-39		Lab ID: R2511649-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8
CLIENT ID: 157.2-40		Lab ID: R2511649-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.3			1.0	ug/L	200.8
CLIENT ID: 157.2-41		Lab ID: R2511649-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.6			1.0	ug/L	200.8
CLIENT ID: 157.2-42		Lab ID: R2511649-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.9			1.0	ug/L	200.8
CLIENT ID: 157.2-43		Lab ID: R2511649-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	25.2			1.0	ug/L	200.8
CLIENT ID: 157.2-44		Lab ID: R2511649-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8
CLIENT ID: 157.2-45		Lab ID: R2511649-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8
CLIENT ID: 157.2-46		Lab ID: R2511649-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.6			1.0	ug/L	200.8
CLIENT ID: 157.2-47		Lab ID: R2511649-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.5			1.0	ug/L	200.8
CLIENT ID: 157.2-48		Lab ID: R2511649-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-49		Lab ID: R2511649-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	18.3			1.0	ug/L	200.8
CLIENT ID: 157.2-50		Lab ID: R2511649-014				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.1			1.0	ug/L	200.8
CLIENT ID: 157.2-51		Lab ID: R2511649-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8
CLIENT ID: 157.2-52		Lab ID: R2511649-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.3			1.0	ug/L	200.8
CLIENT ID: 157.2-53		Lab ID: R2511649-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.8			1.0	ug/L	200.8
CLIENT ID: 157.2-54		Lab ID: R2511649-018				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8
CLIENT ID: 157.2-55		Lab ID: R2511649-019				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	21.8			1.0	ug/L	200.8
CLIENT ID: 157.2-56		Lab ID: R2511649-020				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.8			1.0	ug/L	200.8
CLIENT ID: 157.2-57		Lab ID: R2511649-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.9			1.0	ug/L	200.8
CLIENT ID: 157.2-58		Lab ID: R2511649-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	36.9			1.0	ug/L	200.8
CLIENT ID: 157.2-59		Lab ID: R2511649-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	236			1.0	ug/L	200.8
CLIENT ID: 157.2-60		Lab ID: R2511649-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	11.4			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-61		Lab ID: R2511649-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	26.6			1.0	ug/L	200.8
CLIENT ID: 157.2-62A		Lab ID: R2511649-026				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8
CLIENT ID: 157.2-63		Lab ID: R2511649-027				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.9			1.0	ug/L	200.8
CLIENT ID: 157.2-64		Lab ID: R2511649-028				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	28.1			1.0	ug/L	200.8
CLIENT ID: 157.2-65		Lab ID: R2511649-029				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	16.4			1.0	ug/L	200.8
CLIENT ID: 157.2-66		Lab ID: R2511649-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.9			1.0	ug/L	200.8
CLIENT ID: 157.2-67		Lab ID: R2511649-031				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	18.9			1.0	ug/L	200.8
CLIENT ID: 157.2-68		Lab ID: R2511649-032				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.3			1.0	ug/L	200.8
CLIENT ID: 157.2-69		Lab ID: R2511649-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.8			1.0	ug/L	200.8
CLIENT ID: 157.2-70		Lab ID: R2511649-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	17.7			1.0	ug/L	200.8
CLIENT ID: 157.2-71		Lab ID: R2511649-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.7			1.0	ug/L	200.8
CLIENT ID: 157.2-72		Lab ID: R2511649-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	14.6			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 157.2-73			Lab ID: R2511649-037			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.6			1.0	ug/L	200.8

CLIENT ID: 157.2-74			Lab ID: R2511649-038			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	32.2			1.0	ug/L	200.8

CLIENT ID: 157.2-75			Lab ID: R2511649-039			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	19.9			1.0	ug/L	200.8

CLIENT ID: 157.2-76			Lab ID: R2511649-040			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8

CLIENT ID: 157.2-77			Lab ID: R2511649-041			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	23.7			1.0	ug/L	200.8

CLIENT ID: 157.2-78			Lab ID: R2511649-042			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request:R2511649

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2511649-001	157.2-37	9/13/2025	
R2511649-002	157.2-38	9/13/2025	
R2511649-003	157.2-39	9/13/2025	
R2511649-004	157.2-40	9/13/2025	
R2511649-005	157.2-41	9/13/2025	
R2511649-006	157.2-42	9/13/2025	
R2511649-007	157.2-43	9/13/2025	
R2511649-008	157.2-44	9/13/2025	
R2511649-009	157.2-45	9/13/2025	
R2511649-010	157.2-46	9/13/2025	
R2511649-011	157.2-47	9/13/2025	
R2511649-012	157.2-48	9/13/2025	
R2511649-013	157.2-49	9/13/2025	
R2511649-014	157.2-50	9/13/2025	
R2511649-015	157.2-51	9/13/2025	
R2511649-016	157.2-52	9/13/2025	
R2511649-017	157.2-53	9/13/2025	
R2511649-018	157.2-54	9/13/2025	
R2511649-019	157.2-55	9/13/2025	
R2511649-020	157.2-56	9/13/2025	
R2511649-021	157.2-57	9/13/2025	
R2511649-022	157.2-58	9/13/2025	
R2511649-023	157.2-59	9/13/2025	
R2511649-024	157.2-60	9/13/2025	
R2511649-025	157.2-61	9/13/2025	
R2511649-026	157.2-62A	9/13/2025	
R2511649-027	157.2-63	9/13/2025	
R2511649-028	157.2-64	9/13/2025	
R2511649-029	157.2-65	9/13/2025	
R2511649-030	157.2-66	9/13/2025	
R2511649-031	157.2-67	9/13/2025	
R2511649-032	157.2-68	9/13/2025	
R2511649-033	157.2-69	9/13/2025	
R2511649-034	157.2-70	9/13/2025	
R2511649-035	157.2-71	9/13/2025	
R2511649-036	157.2-72	9/13/2025	
R2511649-037	157.2-73	9/13/2025	
R2511649-038	157.2-74	9/13/2025	
R2511649-039	157.2-75	9/13/2025	
R2511649-040	157.2-76	9/13/2025	
R2511649-041	157.2-77	9/13/2025	
R2511649-042	157.2-78	9/13/2025	



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-157

Client: Lead in Water

Contact: Mr. Kyle Barthel

Building: Forestville ES

Location: 12 Water St, Forestville, NY 14062

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.2-37	Classroom 24 Bathroom Sink	Sink	10:06
157.2-38	Classroom 27 Sink	Sink	10:07
157.2-39	Classroom 27 Fountain	Fountain	10:08
157.2-40	Classroom 27 Bathroom Sink	Sink	10:09
157.2-41	Classroom 26 Sink	Sink	10:10
157.2-42	Classroom 26 Fountain	Fountain	10:11
157.2-43	Classroom 26 Bathroom Sink	Sink	10:12
157.2-44	Classroom 29 Sink	Sink	10:13
157.2-45	Classroom 29 Fountain	Fountain	10:14
157.2-46	Classroom 29 Bathroom Sink	Sink	10:15
157.2-47	Classroom 28 Sink	Sink	10:16
157.2-48	Classroom 28 Fountain	Fountain	10:17
157.2-49	Classroom 28 Bathroom Sink	Sink	10:18
157.2-50	Classroom 31 Steel Sink	Sink	10:19
157.2-51	Classroom 31 Fountain	Sink	10:20
157.2-52	Classroom 31 White Sink	Sink	10:21
157.2-53	Classroom 30 Steel Sink	Sink	10:22
157.2-54	Classroom 30 Fountain	Fountain	10:23

Notes:

Please e-mail lab results to labs@stohlenv.com

Rfranjioine@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By: _____ Print Name Stohl Env: Connor Crilly Date: 9/15/2025

Received (Name / Lab): Thomas Potter Date: 9/16/25 Time: 845

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2511649

5

Stohl Environmental
Forestville ES





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-157

Client: Lead in Water

Contact: Mr. Kyle Barthel

Building: Forestville ES

Location: 12 Water St, Forestville, NY 14062

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
157.2-55	Classroom 30 White Sink	Sink	10:24
157.2-56	Classroom 33 Steel Sink	Sink	10:25
157.2-57	Classroom 33 Fountain	Sink	10:26
157.2-58	Classroom 33 White Sink	Sink	10:27
157.2-59	Classroom 32 Steel Sink	Sink	10:28
157.2-60	Classroom 32 Fountain	Sink	10:29
157.2-61	Classroom 32 White Sink	Sink	10:30
157.2-62A	Outside Custodial Office Bottle Fill	Bottle Fill	10:31
157.2-63	Classroom 34 Steel Sink	Sink	10:32
157.2-64	Classroom 34 Fountain	Fountain	10:33
157.2-65	Classroom 36 Sink	Sink	10:34
157.2-66	Classroom 36 Fountain	Fountain	10:35
157.2-67	Classroom 40 Steel Sink	Sink	10:36
157.2-68	Classroom 40 Fountain	Fountain	10:37
157.2-69	Classroom 39 Sink	Sink	10:38
157.2-70	Classroom 39 Fountain	Fountain	10:39
157.2-71	Classroom 44 Steel Sink	Sink	10:40
157.2-72	Classroom 44 Fountain	Fountain	10:41

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Rfrancoine@stohlenvironmental.com

Sampled By: Sam Lee Print Name Stohl Env: Sam Lee Date: 9/13/2025

Relinquished By: _____ Print Name Stohl Env: Connor Crilly Date: 9/15/2025

Received (Name / Lab): Thomas Potter ALS Date: 9/16/25 Time: 845

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



STOHL Job # 2023L-157

Building: Forestville ES Location: 12 Water St, Forestville, NY 14062

Turnaround

X

10 Days

Notes:

Rfranjoine@stohlenvironmental.com

Archived / Released: QA/QC InterLAB Use: Date: Time:



Cooler Receipt and Preservation Check Form

R2511649

5

Stahl Environmental
Forestville ES

Project/Client

Folder Number

Cooler received on 9/16/25

by: RJP

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> MA
5b	Sig* bubbles: Alk? Y N <input checked="" type="radio"/> MA Sulfide? Y N <input checked="" type="radio"/> MA	
6	Where did the bottles originate?	ALS/ROC CLIENT
7	Soil VOA received as: Bulk Encore 5035set	NA

8. Temperature Readings

Date: 9/16/25 Time: 845

ID: IR#12 (IR#1)

From: Temp Blank Sample Bottle

Temp (°C)							
Within 0-6°C?	Y <input checked="" type="radio"/> N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: metals Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:

All samples held in storage location: SMO by RJP on 9/16 at 847

5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 9/16/25 Time: 1345 by: RJP

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
13. Were dissolved metals filtered in the field? YES NO N/A
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃	✓				all	4mL	242587	≤2
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives)."

Bottle lot numbers: 051225-2ADD

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: RJP

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-37
Lab Code: R2511649-001
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-38
Lab Code: R2511649-002
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-39
Lab Code: R2511649-003
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-40
Lab Code: R2511649-004
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-41
Lab Code: R2511649-005
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-42
Lab Code: R2511649-006
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-43
Lab Code: R2511649-007
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-44
Lab Code: R2511649-008
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-45
Lab Code: R2511649-009
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-46
Lab Code: R2511649-010
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-47
Lab Code: R2511649-011
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-48
Lab Code: R2511649-012
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-49
Lab Code: R2511649-013
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-50
Lab Code: R2511649-014
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-51
Lab Code: R2511649-015
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-52
Lab Code: R2511649-016
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-53
Lab Code: R2511649-017
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-54
Lab Code: R2511649-018
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-55
Lab Code: R2511649-019
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-56
Lab Code: R2511649-020
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-57
Lab Code: R2511649-021
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-58
Lab Code: R2511649-022
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By
ECASTROVINCI

Analyzed By
NMANSEN

Sample Name: 157.2-59
Lab Code: R2511649-023
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-60
Lab Code: R2511649-024
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-61
Lab Code: R2511649-025
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-62A
Lab Code: R2511649-026
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-63
Lab Code: R2511649-027
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-64
Lab Code: R2511649-028
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-65
Lab Code: R2511649-029
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-66
Lab Code: R2511649-030
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-67
Lab Code: R2511649-031
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-68
Lab Code: R2511649-032
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-69
Lab Code: R2511649-033
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-70
Lab Code: R2511649-034
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-71
Lab Code: R2511649-035
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-72
Lab Code: R2511649-036
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-73
Lab Code: R2511649-037
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-74
Lab Code: R2511649-038
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-75
Lab Code: R2511649-039
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 157.2-76
Lab Code: R2511649-040
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: Forestville ES/2023L-157

Service Request: R2511649

Sample Name: 157.2-77
Lab Code: R2511649-041
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 157.2-78
Lab Code: R2511649-042
Sample Matrix: Drinking Water

Date Collected: 09/13/25**Date Received:** 09/16/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-37
Lab Code: R2511649-001

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.7	ug/L	1.0	1	09/18/25 18:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-38
Lab Code: R2511649-002

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.3	ug/L	1.0	1	09/18/25 18:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-39
Lab Code: R2511649-003

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	09/18/25 18:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-40
Lab Code: R2511649-004

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.3	ug/L	1.0	1	09/18/25 18:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-41
Lab Code: R2511649-005

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.6	ug/L	1.0	1	09/18/25 18:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-42
Lab Code: R2511649-006

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.9	ug/L	1.0	1	09/18/25 18:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-43
Lab Code: R2511649-007

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	25.2	ug/L	1.0	1	09/18/25 18:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-44
Lab Code: R2511649-008

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	09/18/25 18:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-45
Lab Code: R2511649-009

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	09/18/25 18:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-46
Lab Code: R2511649-010

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.6	ug/L	1.0	1	09/18/25 18:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-47
Lab Code: R2511649-011

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	09/18/25 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-48
Lab Code: R2511649-012

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	09/18/25 18:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-49
Lab Code: R2511649-013

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.3	ug/L	1.0	1	09/18/25 18:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-50
Lab Code: R2511649-014

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.1	ug/L	1.0	1	09/18/25 18:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-51
Lab Code: R2511649-015

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	09/18/25 18:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-52
Lab Code: R2511649-016

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.3	ug/L	1.0	1	09/18/25 18:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-53
Lab Code: R2511649-017

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.8	ug/L	1.0	1	09/18/25 18:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-54
Lab Code: R2511649-018

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	09/18/25 18:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-55
Lab Code: R2511649-019

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	21.8	ug/L	1.0	1	09/18/25 19:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-56
Lab Code: R2511649-020

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.8	ug/L	1.0	1	09/18/25 19:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-57
Lab Code: R2511649-021

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.9	ug/L	1.0	1	09/18/25 19:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-58
Lab Code: R2511649-022

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	36.9	ug/L	1.0	1	09/22/25 17:36	09/19/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-59
Lab Code: R2511649-023

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	236	ug/L	1.0	1	09/18/25 19:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-60
Lab Code: R2511649-024

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.4	ug/L	1.0	1	09/18/25 19:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-61
Lab Code: R2511649-025

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	26.6	ug/L	1.0	1	09/18/25 19:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-62A
Lab Code: R2511649-026

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	09/18/25 19:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-63
Lab Code: R2511649-027

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.9	ug/L	1.0	1	09/18/25 19:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-64
Lab Code: R2511649-028

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	28.1	ug/L	1.0	1	09/18/25 19:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-65
Lab Code: R2511649-029

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	16.4	ug/L	1.0	1	09/18/25 19:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-66
Lab Code: R2511649-030

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.9	ug/L	1.0	1	09/18/25 19:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-67
Lab Code: R2511649-031

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.9	ug/L	1.0	1	09/18/25 19:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-68
Lab Code: R2511649-032

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.3	ug/L	1.0	1	09/18/25 19:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-69
Lab Code: R2511649-033

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.8	ug/L	1.0	1	09/18/25 19:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-70
Lab Code: R2511649-034

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.7	ug/L	1.0	1	09/18/25 19:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-71
Lab Code: R2511649-035

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	09/22/25 14:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-72
Lab Code: R2511649-036

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.6	ug/L	1.0	1	09/18/25 19:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-73
Lab Code: R2511649-037

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.6	ug/L	1.0	1	09/18/25 19:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-74
Lab Code: R2511649-038

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	32.2	ug/L	1.0	1	09/18/25 19:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-75
Lab Code: R2511649-039

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	19.9	ug/L	1.0	1	09/18/25 19:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-76
Lab Code: R2511649-040

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	09/22/25 14:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-77
Lab Code: R2511649-041

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	23.7	ug/L	1.0	1	09/22/25 14:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: 157.2-78
Lab Code: R2511649-042

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25 08:45
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.3	ug/L	1.0	1	09/22/25 14:55	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2511649-MB1

Service Request: R2511649
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/22/25 17:32	09/19/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 18:08	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2511649-MB2

Service Request: R2511649
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/18/25 18:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2511649-MB3

Service Request: R2511649
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/22/25 14:38	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-54
Lab Code: R2511649-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2511649-018MS		Result	Duplicate Matrix Spike R2511649-018DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0	20.1	20.0	96	20.2	20.0	96	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-55
Lab Code: R2511649-019
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Matrix Spike R2511649-019MS				Duplicate Matrix Spike R2511649-019DMS				RPD Limit
		Result	Spike Amount	% Rec	Result	Spike Amount	% Rec	% Rec Limits	RPD	
Lead, Total	21.8	42.7	20.0	104	42.5	20.0	104	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511649
Date Collected: 09/13/25
Date Received: 09/16/25
Date Analyzed: 09/18/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 157.2-75
Lab Code: R2511649-039
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2511649-039MS		Result	Duplicate Matrix Spike R2511649-039DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	19.9	40.6	20.0	104	40.3	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511649
Date Analyzed: 09/18/25 - 09/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L**Basis:**NA**Lab Control Sample**

R2511649-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.1	20.0	100	85-115
Lead, Total	200.8	20.7	20.0	104	85-115

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511649
Date Analyzed: 09/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2511649-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	102	85-115

Client: Stohl Environmental
Project: Forestville ES/2023L-157
Sample Matrix: Drinking Water

Service Request: R2511649
Date Analyzed: 09/22/25

Lab Control Sample Summary
Inorganic Parameters


Units:ug/L
Basis:NA

Lab Control Sample
R2511649-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.7	20.0	108	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2025
Issued April 01, 2024

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Disinfection By-products	
Bromide	EPA 300.0 Rev. 2.1
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4

Serial No.: 68402

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5

