

October 13, 2016

Mr. John Robertson
Forestville Central School District
Director of Facilities
4 Academy Street
Forestville, NY 14062

re: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. John Robertson:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Forestville Central School District, including:

- Forestville Elementary School, 12 Water Street, Forestville, NY


This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than or equal to the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on September 17, 2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 23 sources of potable water in Forestville Elementary have been identified as having lead concentrations in water at or above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Forestville Central School District.

Sincerely,
Stohl Environmental, LLC.



William K. Sisco
PROJECT MANAGER

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

**Mr. John Robertson
Forestville Central School District
Director of Facilities
4 Academy Street
Forestville, NY 14062**

Prepared by:



ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219

☎ (716) 312-0070 📠 (716) 312-8092

www.stohlenvironmental.com

Conditions as of September 17, 2016

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Forestville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Forestville Elementary School, 12 Water Street, Forestville, NY

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in Forestville Elementary. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water in was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
 - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
 - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

First Draw Samples				Confirmatory Samples **		
Building Name	Total Number of Samples Collected	Number of Samples Analyzed Below the NYS Action level of 15 ppb	Number of Samples Analyzed at or above the NYS Action Level of 15 ppb	Total Number of Samples Collected	Number of Samples Analyzed Below the NYS Action level of 15 ppb	Number of Samples Analyzed Below the NYS Action level of 15 ppb
Forestville Elementary	84	61	23	0	0	0

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

A MEMBER OF THE STOHL GROUP OF COMPANIES

Locations of Samples Analyzed at or above the NYS Action Level of 15 parts per billion			
Sample #	Classroom or other Location	Outlet type	Laboratory Analysis
101.3-5	Classroom 12	Sink	19.0
101.3-16	Business Office	Sink (incorrectly listed as Bubbler on chain and lab reports)	16.3
101.3-17	Men's Lavatory Sink	Sink	16.7
101.3-29	Kitchen South Wall Sink	Sink	54.2
101.3-33	Gym Teacher Office Sink	Sink	82.5
101.3-34	Girls Locker Room Sink	Sink	22.0
101.3-49	Classroom 29	Steel Sink	27.8
101.3-55	Classroom 31	Steel Sink	23.6
101.3-58	Classroom 30	Steel Sink	15.7
101.3-61	Classroom 33	Steel Sink	103
101.3-69	Classroom 36	Sink	69.1
101.3-70	Classroom 36	Bubbler	32.6
101.3-71	Classroom 40	Steel Sink	60.0
101.3-72	Classroom 40	Bubbler	24.9
101.3-74	Classroom 39	Bubbler	39.5
101.3-77	Classroom 41	Sink	23.9
101.2-78	Classroom 41	Bubbler	26.5
101.3-79	Hose Bib, 1 st North of front doors	Hose Bib	45.1
101.3-80	Hose Bib, 2 nd North of front doors	Hose Bib	108
101.3-81	Hose Bib, North side of building	Hose Bib	2140
101.3-82	Hose Bib, Northeast most	Hose Bib	74.3
101.3-83	Hose Bib, East central	Hose Bib	554
101.3-84	Hose Bib, Southeast	Hose Bib	48.9

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.4 Laboratory Analytical Reports by Building



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 09/29/16
Reported 10/03/16

PO Number:

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

Sample ID Parameter	Cust. Sample ID	Location Method	Sample Date	Result	RL*	Units	Analyst
185406-001	101.3-1 WMF	Water Main Outside Hose					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-002	101.3-2 WMTC	Water Main Outside Hose					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-003	101.3-3	Classroom 13 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	12.0	5.00	µg/L	SA
185406-004	101.3-4	Classroom 13 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-005	101.3-5	Classroom 12 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	19.0	5.00	µg/L	SA
185406-006	101.3-6	Classroom 12 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.21	5.00	µg/L	SA
185406-007	101.3-7	Classroom 11 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	13.9	5.00	µg/L	SA
185406-008	101.3-8	Classroom 11 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	9.11	5.00	µg/L	SA
185406-009	101.3-9	Classroom 10 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	10.5	5.00	µg/L	SA
185406-010	101.3-10	Classroom 10 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.91	5.00	µg/L	SA
185406-011	101.3-11	Classroom 9 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-012	101.3-12	Classroom 9 Bubblers					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.20	5.00	µg/L	SA
185406-013	101.3-13	Classroom 8 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	9.65	5.00	µg/L	SA
185406-014	101.3-14	Classroom 6 Staff Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	13.5	5.00	µg/L	SA
185406-015	101.3-15	Classroom 6 Staff Bubblers					

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAP standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 09/29/16
Reported 10/03/16

Attn:

Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
Lead		EPA 200.9 Rev 2.2	09/17/16	12.5	5.00	µg/L	SA
185406-016	101.3-16	Business Office Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	16.3	5.00	µg/L	SA
185406-017	101.3-17	Men's Lavatory Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	16.7	5.00	µg/L	SA
185406-018	101.3-18	Girls Bathroom W Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-019	101.3-19	Girls Bathroom E Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.02	5.00	µg/L	SA
185406-020	101.3-20	Mop Room Janitor Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-021	101.3-21	Boys Bathroom W Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.71	5.00	µg/L	SA
185406-022	101.3-22	Boys Bathroom E Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	8.41	5.00	µg/L	SA
185406-023	101.3-23	Staff Bathroom Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-024	101.3-24	Psychology Room Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	11.8	5.00	µg/L	SA
185406-025	101.3-25	DF Cafeteria DF					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-026	101.3-26	Sink N Wall Kitchen Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.22	5.00	µg/L	SA
185406-027	101.3-27	Kitchen Bathroom Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	13.6	5.00	µg/L	SA
185406-028	101.3-28	Kitchen E Wall Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	8.17	5.00	µg/L	SA
185406-029	101.3-29	Kitchen S Wall Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	54.2	10.0	µg/L	SA

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 09/30/16
Reported 10/03/16

PO Number:

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
185406-030	101.3-30	Nurse BR Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-031	101.3-31	Nurse Exam Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-032	101.3-32	DF Hallway Near Gym DF					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-033	101.3-33	Gym Teacher Office Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	82.5	25.0	µg/L	SA
185406-034	101.3-34	Girls Locker Room Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	22.0	5.00	µg/L	SA
185406-035	101.3-35	Girls Locker Room Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.01	5.00	µg/L	SA
185406-036	101.3-36	Boys Locker Room Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	10.3	5.00	µg/L	SA
185406-037	101.3-37	Classroom 25 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-038	101.3-38	Classroom 25 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-039	101.3-39	Classroom 25 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.88	5.00	µg/L	SA
185406-040	101.3-40	Classroom 24 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-041	101.3-41	Classroom 24 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-042	101.3-42	Classroom 24 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.17	5.00	µg/L	SA
185406-043	101.3-43	Classroom 27 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-044	101.3-44	Classroom 27 Bubbler					

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 09/30/16
Reported 10/03/16

Attn:

Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-045	101.3-45	Classroom 27 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.65	5.00	µg/L	SA
185406-046	101.3-46	Classroom 26 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	6.39	5.00	µg/L	SA
185406-047	101.3-47	Classroom 26 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-048	101.3-48	Classroom 26 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.67	5.00	µg/L	SA
185406-049	101.3-49	Classroom 29 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	27.8	5.00	µg/L	SA
185406-050	101.3-50	Classroom 29 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-051	101.3-51	Classroom 29 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.84	5.00	µg/L	SA
185406-052	101.3-52	Classroom 28 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.50	5.00	µg/L	SA
185406-053	101.3-53	Classroom 28 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-054	101.3-54	Classroom 28 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-055	101.3-55	Classroom 31 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	23.6	5.00	µg/L	SA
185406-056	101.3-56	Classroom 31 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.77	5.00	µg/L	SA
185406-057	101.3-57	Classroom 31 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-058	101.3-58	Classroom 30 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	15.7	5.00	µg/L	SA

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 09/30/16
Reported 10/03/16

PO Number:

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
185406-059	101.3-59	Classroom 30 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-060	101.3-60	Classroom 30 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-061	101.3-61	Classroom 33 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	103	25.0	µg/L	SA
185406-062	101.3-62	Classroom 33 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	8.90	5.00	µg/L	SA
185406-063	101.3-63	Classroom 33 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-064	101.3-64	Classroom 32 White Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	10.3	5.00	µg/L	SA
185406-065	101.3-65	Outside Custodian Door DF					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA
185406-066	101.3-66	Women's Lavatory Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	5.70	5.00	µg/L	SA
185406-067	101.3-67	Classroom 34 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	7.16	5.00	µg/L	SA
185406-068	101.3-68	Classroom 34 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16				
Sample not used							
185406-069	101.3-69	Classroom 36 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	69.1	25.0	µg/L	SA
185406-070	101.3-70	Classroom 36 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	32.6	5.00	µg/L	SA
185406-071	101.3-71	Classroom 40 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	60.0	25.0	µg/L	SA
185406-072	101.3-72	Classroom 40 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	24.9	5.00	µg/L	SA

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 10/01/16
Reported 10/03/16

PO Number:

Attn:
Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					
185406-073	101.3-73	Classroom 39 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	14.5	5.00	µg/L	SA
185406-074	101.3-74	Classroom 39 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	39.5	5.00	µg/L	SA
185406-075	101.3-75	Classroom 44 Steel Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	9.95	5.00	µg/L	SA
185406-076	101.3-76	Classroom 44 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	10.8	5.00	µg/L	SA
185406-077	101.3-77	Classroom 41 Sink					
Lead		EPA 200.9 Rev 2.2	09/17/16	23.9	5.00	µg/L	SA
185406-078	101.3-78	Classroom 41 Bubbler					
Lead		EPA 200.9 Rev 2.2	09/17/16	26.5	5.00	µg/L	SA
185406-079	101.3-79	Hose Bib 1st N Ft Doors					
Lead		EPA 200.9 Rev 2.2	09/17/16	45.1	10.0	µg/L	SA
185406-080	101.3-80	Hose Bib 2nd N Ft Doors					
Lead		EPA 200.9 Rev 2.2	09/17/16	108	25.0	µg/L	SA
185406-081	101.3-81	Hose Bib N Side Building					
Lead		EPA 200.9 Rev 2.2	09/17/16	2140	500	µg/L	SA
185406-082	101.3-82	Hose Bib NE Most					
Lead		EPA 200.9 Rev 2.2	09/17/16	74.3	25.0	µg/L	SA
185406-083	101.3-83	Hose Bib					
Lead		EPA 200.9 Rev 2.2	09/17/16	554	100	µg/L	SA
185406-084	101.3-84	Hose Bib					
Lead		EPA 200.9 Rev 2.2	09/17/16	48.9	10.0	µg/L	SA
185406-085	101.3-85	Hose Bib SW					
Lead		EPA 200.9 Rev 2.2	09/17/16	< 5.00	5.00	µg/L	SA

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 185406

Matrix Water
Received 09/21/16
Analyzed 10/01/16
Reported 10/03/16

Attn:

Project: Forestville Elementary
Location: 12 Water St Forestville NY
Number: 2016L-101.3

PO Number:

Sample ID	Cust. Sample ID	Location	Sample Date	Result	RL*	Units	Analyst
Parameter		Method					

185406-10/03/16 03:34 PM

Abisola O Kasali

Reviewed By: **Abisola Kasali**

Metals Supervisor

*Reporting Limit. All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. The test results reported relate only to the samples submitted. Values are reported to three significant figures. The signature above certifies that all results conform to the current NELAC standards unless otherwise noted.



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-1 WMF	water main outside hose bib	Hose Bib	7:28	NA		
101.3-2 WMTC	water main outside hose bib	Hose Bib	7:28	NA		
101.3-3	Classroom 13	Sink	7:40	NA		
101.3-4	Classroom 13	Bubbler	7:41	NA		
101.3-5	Classroom 12	Sink	7:48	NA		
101.3-6	Classroom 12	Bubbler	7:49	NA		
101.3-7	Classroom 11	Sink	7:54	NA		
101.3-8	Classroom 11	Bubbler	7:54	NA		
101.3-9	Classroom 10	Sink	7:53	NA		
101.3-10	Classroom 10	Bubbler	7:53	NA		
101.3-11	Classroom 9	Sink	7:59	NA		
101.3-12	Classroom 9	Bubbler	8:00	NA		
101.3-13	Classroom 8	Sink	8:03	NA		
101.3-14	Classroom 6 - Staff Lounge	Sink	8:09	NA		
101.3-15	Classroom 6 - Staff Lounge	Bubbler	8:10	NA		
101.3-16	Business Office	Bubbler	8:12	NA		
101.3-17	Men's Lavatory	Sink	10:17	NA		
101.3-18	Girls Bathroom - West sink	Sink	8:14	NA		

185406

S 84



V:\185\185406

fghraizi
Federal Express

9/21/2016 2:45:00 PM
77726 3873821

Notes:

Please e-mail lab results to labs@stohlenv.com

☐ If checked, also e-mail results to: _____

Sampled By: Wu Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Wu Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-19	Girls Bathroom - East sink	Sink	8:15	NA		
101.3-20	Mop Room	Janitor Sink	8:24	NA		
101.3-21	Boys Bathroom - West Sink	Sink	8:27	NA		
101.3-22	Boys Bathroom - East Sink	Sink	8:27	NA		
101.3-23	Staff bathroom	Sink	8:25	NA		
101.3-24	Psychology room	Sink	8:29	NA		
101.3-25	DF cafeteria	DF	8:38	NA		
101.3-26	Sink north wall kitchen	Sink	8:41	NA		
101.3-27	Kitchen bathroom	Sink	8:42	NA		
101.3-28	Kitchen East Wall	Sink	8:39	NA		
101.3-29	Kitchen - South Wall	Sink	8:40	NA		
101.3-30	Nurse br	Sink	8:48	NA		
101.3-31	Nurse exam	Sink	8:50	NA		
101.3-32	DF hallway near gym	Drinking Fountain	8:55	Elkay, model: lzwsr1c		
101.3-33	Gym Teacher Office	Sink	9:00	NA		
101.3-34	Girls Locker Room	Sink	9:01	NA		
101.3-35	Girls Locker Room	Bubbler	9:06	NA		
101.3-36	Boys locker room sink	Sink	9:00	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-37	Classroom 25 - Steel sink	Sink	9:15	NA		
101.3-38	Classroom 25	Bubbler	9:15	NA		
101.3-39	Classroom 25 - White sink	Sink	9:16	NA		
101.3-40	Classroom 24, steel sink	Sink	9:23	NA		
101.3-41	Classroom 24, bubbler	Bubbler	9:26	NA		
101.3-42	Classroom 24, white sink	Sink	9:28	NA		
101.3-43	Classroom 27 - Steel sink	Sink	9:28	NA		
101.3-44	Classroom 27	Bubbler	9:28	NA		
101.3-45	Classroom 27 - White sink	Sink	9:29	NA		
101.3-46	Classroom 26, steel sink	Sink	9:32	NA		
101.3-47	Classroom 26, bubbler	bubbler	9:34	NA		
101.3-48	Classroom 26, white sink	Sink	9:36	NA		
101.3-49	Classroom 29 - Steel sink	Sink	9:37	NA		
101.3-50	Classroom 29	bubbler	9:37	NA		
101.3-51	Classroom 29 - White Sink	Sink	9:38	NA		
101.3-52	Classroom 28, steel sink	Sink	9:38	NA		
101.3-53	Classroom, 28, bubbler	Bubbler	9:41	NA		
101.3-54	Classroom 28, white sink	Sink	9:43	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: William F... Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William F... Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-55	Classroom 31 - Steel sink	Sink	9:41	NA		
101.3-56	Classroom 31	bubbler	9:41	NA		
101.3-57	Classroom 31 - White sink	Sink	9:42	NA		
101.3-58	Classroom 30, steel sink	Sink	9:49	NA		
101.3-59	Classroom 30, bubbler	bubbler	9:50	NA		
101.3-60	Classroom 30, white sink	Sink	9:53	NA		
101.3-61	Classroom 33 - Steel sink	Sink	9:51	NA		
101.3-62	Classroom 33	bubbler	9:51	NA		
101.3-63	Classroom 33 - White sink	Sink	9:52	NA		
101.3-64	Classroom 32, white sink	Sink	9:56	NA		
101.3-65	Outside custodian door	Drinking Fountain	10:03	NA		
101.3-66	Women's Lavatory	Sink	10:09	NA		
101.3-67	Classroom 34, steel sink	Sink	10:22	NA		
101.3-68	Classroom 34, bubbler	bubbler	10:23	NA		
101.3-69	Classroom 36	Sink	10:23	NA		
101.3-70	Classroom 36	Bubbler	10:23	NA		
101.3-71	Classroom 40, steel sink	Sink	10:30	NA		
101.3-72	Classroom 40, bubbler	Bubbler	10:32	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Willie Green Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: Willie Green Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-73	Classroom 39	Sink	10:33	NA		
101.3-74	Classroom 39	Bubbler	10:33	NA		
101.3-75	Classroom 44, steel sink	Sink	10:37	NA		
101.3-76	Classroom 44, bubbler	Bubbler	10:39	NA		
101.3-77	Classroom 41	Sink	10:38	NA		
101.3-78	Classroom 41	Bubbler	10:38	NA		
101.3-79	Hose bib, 1st N of ft doors	Hose Bib	11:08	NA		
101.3-80	Hose bib, 2nd N of ft doors	Hose bib	11:14	NA		
101.3-81	Hose bib, north side of build.	Hose bib	11:19	NA		
101.3-82	Hose bib, northeast most	Hose bib	11:23	NA		
101.3-83	Hose bib	Hose bib	11:27	NA		
101.3-84	Hose bib	Hose bib	11:34	NA		
101.3-85	Hose bib, southwest	Hose bib	11:37	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: William F... Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William F... Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued September 22, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Lead, Total

EPA 200.9 Rev. 2.2



Department
of Health

Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES NON POTABLE WATER
All approved analytes are listed below:*

Metals I

Lead, Total

EPA 200.7 Rev. 4.4
EPA 6010C
EPA 7000B
EPA 200.9 Rev. 2.2

Sample Preparation Methods

EPA 3010A
EPA 3005A
EPA 3020A



Department
of Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved analytes are listed below:*

Characteristic Testing

TCLP EPA 1311

Metals I

Barium, Total EPA 6010C
Cadmium, Total EPA 6010C
Chromium, Total EPA 6010C
Lead, Total EPA 6010C
Nickel, Total EPA 7000B
Silver, Total EPA 6010C

Metals II

Antimony, Total EPA 6010C
Arsenic, Total EPA 6010C
Chromium VI EPA 7196A
Mercury, Total EPA 7471B
Selenium, Total EPA 6010C

Polychlorinated Biphenyls

PCB-1016 EPA 8082A
PCB-1221 EPA 8082A
PCB-1232 EPA 8082A
PCB-1242 EPA 8082A
PCB-1248 EPA 8082A
PCB-1254 EPA 8082A
PCB-1260 EPA 8082A
PCB-1262 EPA 8082A

Polychlorinated Biphenyls

PCB-1268 EPA 8082A

Sample Preparation Methods

EPA 3010A
EPA 3050B
EPA 3550C
EPA 3031



Department
of Health

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Miscellaneous

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

Sample Preparation Methods

EPA 3050B



Serial No.: 54669

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS
All approved subcategories and/or analytes are listed below:*

Metals I

Lead, Total NIOSH 7082
 40 CFR PART 50 1984 APP G

Miscellaneous

Fibers NIOSH 7400 A RULES



Serial No.: 54670

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.6 Chains of Custody



Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-1 WMF	water main outside hose bib	Hose Bib	7:28	NA		
101.3-2 WMTC	water main outside hose bib	Hose Bib	7:28	NA		
101.3-3	Classroom 13	Sink	7:40	NA		
101.3-4	Classroom 13	Bubbler	7:41	NA		
101.3-5	Classroom 12	Sink	7:48	NA		
101.3-6	Classroom 12	Bubbler	7:49	NA		
101.3-7	Classroom 11	Sink	7:54	NA		
101.3-8	Classroom 11	Bubbler	7:54	NA		
101.3-9	Classroom 10	Sink	7:53	NA		
101.3-10	Classroom 10	Bubbler	7:53	NA		
101.3-11	Classroom 9	Sink	7:59	NA		
101.3-12	Classroom 9	Bubbler	8:00	NA		
101.3-13	Classroom 8	Sink	8:03	NA		
101.3-14	Classroom 6 - Staff Lounge	Sink	8:09	NA		
101.3-15	Classroom 6 - Staff Lounge	Bubbler	8:10	NA		
101.3-16	Business Office	Bubbler	8:12	NA		
101.3-17	Men's Lavatory	Sink	10:17	NA		
101.3-18	Girls Bathroom - West sink	Sink	8:14	NA		

Note: outlet type should be "Sink"

Notes:

Please e-mail lab results to labs@stohlenv.com

☐ If checked, also e-mail results to: _____

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-19	Girls Bathroom - East sink	Sink	8:15	NA		
101.3-20	Mop Room	Janitor Sink	8:24	NA		
101.3-21	Boys Bathroom - West Sink	Sink	8:27	NA		
101.3-22	Boys Bathroom - East Sink	Sink	8:27	NA		
101.3-23	Staff bathroom	Sink	8:25	NA		
101.3-24	Psychology room	Sink	8:29	NA		
101.3-25	DF cafeteria	DF	8:38	NA		
101.3-26	Sink north wall kitchen	Sink	8:41	NA		
101.3-27	Kitchen bathroom	Sink	8:42	NA		
101.3-28	Kitchen East Wall	Sink	8:39	NA		
101.3-29	Kitchen - South Wall	Sink	8:40	NA		
101.3-30	Nurse br	Sink	8:48	NA		
101.3-31	Nurse exam	Sink	8:50	NA		
101.3-32	DF hallway near gym	Drinking Fountain	8:55	Elkay, model: lzwsr1c		
101.3-33	Gym Teacher Office	Sink	9:00	NA		
101.3-34	Girls Locker Room	Sink	9:01	NA		
101.3-35	Girls Locker Room	Bubbler	9:06	NA		
101.3-36	Boys locker room sink	Sink	9:00	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-37	Classroom 25 - Steel sink	Sink	9:15	NA		
101.3-38	Classroom 25	Bubbler	9:15	NA		
101.3-39	Classroom 25 - White sink	Sink	9:16	NA		
101.3-40	Classroom 24, steel sink	Sink	9:23	NA		
101.3-41	Classroom 24, bubbler	Bubbler	9:26	NA		
101.3-42	Classroom 24, white sink	Sink	9:28	NA		
101.3-43	Classroom 27 - Steel sink	Sink	9:28	NA		
101.3-44	Classroom 27	Bubbler	9:28	NA		
101.3-45	Classroom 27 - White sink	Sink	9:29	NA		
101.3-46	Classroom 26, steel sink	Sink	9:32	NA		
101.3-47	Classroom 26, bubbler	bubbler	9:34	NA		
101.3-48	Classroom 26, white sink	Sink	9:36	NA		
101.3-49	Classroom 29 - Steel sink	Sink	9:37	NA		
101.3-50	Classroom 29	bubbler	9:37	NA		
101.3-51	Classroom 29 - White Sink	Sink	9:38	NA		
101.3-52	Classroom 28, steel sink	Sink	9:38	NA		
101.3-53	Classroom, 28, bubbler	Bubbler	9:41	NA		
101.3-54	Classroom 28, white sink	Sink	9:43	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com _____

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) Schneider

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
(716) 312-0070 (716) 312-8092
www.stohlenvironmental.com

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-55	Classroom 31 - Steel sink	Sink	9:41	NA		
101.3-56	Classroom 31	bubbler	9:41	NA		
101.3-57	Classroom 31 - White sink	Sink	9:42	NA		
101.3-58	Classroom 30, steel sink	Sink	9:49	NA		
101.3-59	Classroom 30, bubbler	bubbler	9:50	NA		
101.3-60	Classroom 30, white sink	Sink	9:53	NA		
101.3-61	Classroom 33 - Steel sink	Sink	9:51	NA		
101.3-62	Classroom 33	bubbler	9:51	NA		
101.3-63	Classroom 33 - White sink	Sink	9:52	NA		
101.3-64	Classroom 32, white sink	Sink	9:56	NA		
101.3-65	Outside custodian door	Drinking Fountain	10:03	NA		
101.3-66	Women's Lavatory	Sink	10:09	NA		
101.3-67	Classroom 34, steel sink	Sink	10:22	NA		
101.3-68	Classroom 34, bubbler	bubbler	10:23	NA		
101.3-69	Classroom 36	Sink	10:23	NA		
101.3-70	Classroom 36	Bubbler	10:23	NA		
101.3-71	Classroom 40, steel sink	Sink	10:30	NA		
101.3-72	Classroom 40, bubbler	Bubbler	10:32	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
☎ (716) 312-0070 ■ (716) 312-8092
www.stohlenvironmental.com

Submitted to: (Lab Name) Schneider

STOHL Job # 2016L-101.3

Client: Forestville CSD

Contact: John Robertson

Building: Forestville Elementary

Location: 12 Water St., Forestville, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

5 days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
101.3-73	Classroom 39	Sink	10:33	NA		
101.3-74	Classroom 39	Bubbler	10:33	NA		
101.3-75	Classroom 44, steel sink	Sink	10:37	NA		
101.3-76	Classroom 44, bubbler	Bubbler	10:39	NA		
101.3-77	Classroom 41	Sink	10:38	NA		
101.3-78	Classroom 41	Bubbler	10:38	NA		
101.3-79	Hose bib, 1st N of ft doors	Hose Bib	11:08	NA		
101.3-80	Hose bib, 2nd N of ft doors	Hose bib	11:14	NA		
101.3-81	Hose bib, north side of build.	Hose bib	11:19	NA		
101.3-82	Hose bib, northeast most	Hose bib	11:23	NA		
101.3-83	Hose bib	Hose bib	11:27	NA		
101.3-84	Hose bib	Hose bib	11:34	NA		
101.3-85	Hose bib, southwest	Hose bib	11:37	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/17/2016

Relinquished By: William Sisco Print Name Stohl Env: Bill Sisco Date: 9/19/2016

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____